

DISTRIBUTION SYSTEM

CAPABILITY STATEMENT
(2025-2027)

DELIVER

CARE

DO BETTER



PREFACE

This Distribution System Capability Statement (DSCS) is provided by Nama Electricity Distribution Company (NEDC) to fulfil its regulatory obligations under Condition number 33 of the NEDC Distribution Licence as well as the Oman Distribution Planning Code 4.4.

NEDC is distributing electricity to customers throughout the Sultanate of Oman excluding Dhofar Governorate as the owner and operator of its electricity distribution system originating from the 33kV busbars at 132/33kV grid substations owned by Oman Electricity Transmission Company down to the final customer's point of connection, which incorporates 33kV, 11kV and Low Voltage (LV) distribution system voltage levels and associated assets.

The aim of this DSCS is to provide an up-to-date distribution system capability for the next three years (2025-2027) along with data to enable customers in identifying parts of the system, which offer opportunities for future connections or upgrading of existing connections to the NEDC system and where constraints currently exist or potentially could exist in future.

In addition to the required data made available annually as part of DSCS; NEDC additionally has provided improved detailed system connectivity and additional technical data of assets, impact analysis of Cost Reflective Tariff (CRT) on NEDC customers and an overview of the technologies contributing to Oman's net zero target by 2050, particularly the increasing penetration of photovoltaic (PV) systems in the NEDC distribution network, which is gaining momentum in our licensed area. These additions are expected to provide customers and other stakeholders with a transparent understanding of NEDC distribution system and operational overview, sufficient technical parameters to undertake initial system capabilities assessment and the overall distribution system development.

NEDC have determined this three-year plan to clarify and highlight NEDC's key priorities over the DSCS planning period. The plan will form the basis for the company's investments to provide economic and efficient system development along with serving to inform NEDC's contributions to the Oman electricity sector and in turn aligning with the Oman Vision 2040 goals.

Eng. Ala Hassan Al Lawati

Chief Executive Officer



TABLE OF CONTENTS

PREFACE	1
LIST OF TABLES	3
LIST OF FIGURES	4
LIST OF ABBREVIATIONS	5
1. INTRODUCTION	1
1.1. WHO WE ARE & WHAT WE DO	1
1.2. NEDC KEY STATISTICAL DATA	3
1.3. PURPOSE OF STATEMENT	3
1.4. STRUCTURE OF THIS DSCS	4
2. PLANNING PHILOSOPHIES AND PRACTICES	5
2.1. GOVERNING STANDARD	5
2.2. SYSTEM CHARACTERISTIC	5
2.2.1 System Parameters:	5
2.2.2 Voltage regulation:	6
2.2.3 Frequency Deviation:	6
2.2.4 Voltage Waveform Quality:	6
2.2.5 Voltage Fluctuation:	6
2.2.6 Distribution System Security Standard (DSSS):	6
2.3. SYSTEM CONFIGURATION	7
2.3.1 33 kV system:	7
2.3.2 11 kV System:	9
2.3.3 Low Voltage System:	11
2.3.4 Small Scale Grid Connected Solar PV Systems:	11
2.3.5 Electric Vehicles (EV) Charging Technical Requirements:	11
2.4. SELECTION OF ASSET	11
2.5. DETAILS ASSET DATA	12
3. PLANNING DRIVERS	13
3.1. BACKGROUND	13
3.2. MUSCAT GOVERNORATE	14
3.2.1. Wilayat Muscat	14
3.2.2. Wilayat Muttrah	14
3.2.3. Wilayat Amerat	14
3.2.4. Wilayat Quriyat	14
3.2.5. Wilayat Bousher	14
3.2.6. Wilayat Seeb	14
3.3. SOUTH AL BATINAH GOVERNORATE	20
3.4. AL DAKHILIAH GOVERNORATE	23
3.5. NORTH AL SHARQIYAH GOVERNORATE	26
3.6. SOUTH AL SHARQIYAH GOVERNORATE	28
3.7. AL WUSTA GOVERNORATE AND SURROUNDING AREAS	30
3.8. AL BURAYMI GOVERNORATE	32
3.9. AL DHAHIRAH GOVERNORATE	33
3.10. NORTH AL BATINAH GOVERNORATE	35
3.10.1. Wilayat Shinas	35
3.10.2. Wilayat Sohar	35
3.10.3. Wilayat Saham	35

3.10.4. Wilayat Al Khabourah	35
3.11. MUSANDAM GOVERNORATE	38
4. NEDC DISTRIBUTION SYSTEM	40
4.1. INTRODUCTION.....	40
4.2. SYSTEM DEMAND AND LOAD DURATION.....	41
4.3. COST REFLECTIVE TARIFF (CRT)	43
4.4. DEMAND NOT SECURED (DNS)	44
4.5. 11KV FEEDER LOADINGS.....	45
4.6. SYSTEM DEMAND FORECAST	48
4.6.1. Load Forecasting	49
4.6.2. System Demand Growth	49
4.7. DISTRIBUTION SYSTEM MODELLING AND ANALYSIS	52
4.7.1. Power System Models	52
4.7.2. Load Flow Analysis	53
4.7.3. Short Circuit Analysis.....	54
4.7.4. Technical Losses Assessment	56
5. CHALLENGES AND OPPORTUNITIES WITHIN THE SYSTEM	57
5.1. MEETING OMAN'S NET-ZERO 2050	57
5.1.1. Photovoltaic (PV) connections	57
6. THE INVESTMENT PLAN	60
6.1. FUTURE SYSTEM DEVELOPMENT PLANS	60
6.2. NETWORK SUITABILITY FOR NEW CONNECTIONS	61
6.3. SYSTEM CONSTRAINTS	61
APPENDIX A: DISTRIBUTION LICENCE CONDITION 33: DSCS	62
APPENDIX B: SYSTEM STUDY RESULTS	64
APPENDIX C: FUTURE SYSTEM DEVELOPMENT PLANS	66
APPENDIX D: SPONSORED PEOJECTS	71

LIST OF TABLES

Table 1: NEDC key statistical data	3
Table 2: System Parameter	5
Table 3: Voltage Regulation	6
Table 4: Distribution System Security Standards DSSS	7
Table 5: Number of 33/11 kV transformers	8
Table 6: Current Ratings of Bus Bar, Bus-section, Transformer, and Feeder Bays	8
Table 7: Number of distribution transformers	10
Table 8: Standard Substation Size and Rating	11
Table 9: Muscat Governorate - Grid and Primary Substations Connectivity	14
Table 10 : South Al Batinah Governorate - Grid and Primary Substations Connectivity	20
Table 11: Al Dakhiliah Governorate- Grid and Primary Substations Connectivity	23
Table 12 :North Al Sharqiyah Areas – Power Plant, Grid, PDO and Primary Substations Connectivity	26
Table 13:South Al Sharqiyah Areas – Power Plant, Grid, PDO and Primary Substations Connectivity	28
Table 14 : AL Wusta Governorate and Surrounding Areas – Power Plant, Grid, PDO and Primary Substations Connectivity	30
Table 15 : Al Buraymi Governorate - Grid and Primary Substations Connectivity	32
Table 16: AL Dhahirah Governorate - Grid and Primary Substations Connectivity	33
Table 17: North AL Batinah Governorate - Grid and Primary Substations Connectivity	35
Table 18: Musandam Governorate - Grid and Primary Substations Connectivity	39
Table 19: Summery of Firm Capacity and Max Load per Governorate	40
Table 20: 11kV Highly Loaded feeder Plan	45
Table 21 : NEDC Non-Coincidence Forecast with Growth	50
Table 22: Al Wusta Diesel Plants	51
Table 23 : Technical Losses	56
Table 24: 2024 PV connection Applications with total installed PV capacity	58
Table 25: A summary of the 33 kV Expansion Plan	60
Table 26: A summary of the Sponsored Projects	60
Table 27: Summary of Connected Customer during 2024	61

LIST OF FIGURES

Figure 1: NEDCs Licenses Area	2
Figure 2: Utilization % from Firm Capacity per Governorate	40
Figure 3: System Max Demand (MW) MIS	41
Figure 4: System Max Demand (MW) Al Wusta	42
Figure 5: System Max Demand (MW) Musandam.....	42
Figure 6 : Hourly Demand – MIS System Maximum and Minimum Day Profile	43
Figure 7 : Hourly Demand – Musandam System Maximum and Minimum Day Profile	43
Figure 8: CRT Customer During System Peak 26 Jun 2024	44
Figure 9 : History of NEDC Demand Not Secured and Out of Firm PSS	45
Figure 10 : Historical Trend in NEDC System Maximum Demand with Three Years Forecast.....	50
Figure 11 : Musandam 2018-2026 Peak Load with Growth percentage	51
Figure 12 : Al Wusta 2018-2026 Peak Load with Growth percentage.....	52
Figure 13: Number of PV Applications.....	59
Figure 14: Connected Generation from PV [MW]	59

LIST OF ABBREVIATIONS

APSR Authority for Public Services Regulation (formerly known as AER - Authority for Electricity Regulation)

CAGR	Compound Annual Growth Rate
CRT	Cost Reflective Tariff
DCC	Distribution Connection Code
DlgSILENT	Digital Simulation and Electrical Network calculation program
DNS	Demand Not Secured
DPC	Distribution Planning Code
DSCS	Distribution System Capability Statement
DSSS	Distribution System Security Standard
D&SL	Distribution & Supply Licence
DL	Distribution Licence
ETAP	Electrical Transient and Analysis Program
EV	Electrical Vehicles
GSS	Grid Substation
IEC	International Electro Technical Commission
NEDC	Nama Electricity Distribution Company
OES	Oman Electrical Standards
OETC	Oman Electricity Transmission Company
PCR-5	Price Control Review-5 (2018-2021)
PCR-6	Price Control Review-6 (2022-2025)
PSS	Primary Substation
PSS®SINCAL	Power System Simulator® Siemens Network Calculation
PV	Photovoltaic
SCADA	Supervisory Control and Data Acquisition

Document Issue and Approval	
Issued Date:	31 st October 2024
Author:	Planning Department
Name of Document:	Three - Year Distribution System Capability Statement (2025-2027)
Document Version:	V 1.0
Quality Assurance & Approval	
Reviewer 1: Section Head 33kV Planning Zone 2	Bader Ali Al Washahi
Reviewer 2: Acting / 33kV Planning Manager	Aisha Saif Al Muqarshi
Reviewer 3: General Manager Planning	Mohammed Salim Al-Ghenaimi
Authorisation to Issue	
Chief Commercial Officer	Khalfan Naser Al Burtamani
Chief Technical Officer	Yousuf Mohammed Al Mahrooqi
Chief Executive Officer	Ala Hassan Al Lawati

Contact details for further info:

Request for a copy of this DSCS, the associated system studies or for any assistance in interpreting or clarifying any information contained within it; please contact:

NEDC 33kV Planning Team

P.O. Box: 1239 Hamriyah

P.C. 131 - Oman

Email: systemplanning@distribution.nama.om

1. INTRODUCTION

1.1. Who We Are & What We Do

The electricity sector in the Sultanate of Oman has been extensively restructured following the law's implementation to regulate and privatize the electricity and related water sector ("**The Sector Law**"). Royal Decree 78/2004 promulgated the Law for the Regulation and Privatisation of the Electricity and Related Water Sector. Article 90 of the DL places an obligation on Distribution Companies to undertake financing, operation, maintenance, development, and expansion of the distribution system in a safe, economic and efficient manner and in accordance with the relevant performance and security standards.

In 2022 a direction has been taken to merge all Distribution Companies (excluding Dhofar Governorate). In June 2023 Nama Electricity Distribution Company (NEDC) has been established and it is under the umbrella of the Nama with an obligation to undertake financing, operation, maintenance, development, and expansion of the distribution system in a safe, economic and efficient manner.

The company offers a diverse and comprehensive portfolio of services aimed at ensuring the seamless operation, expansion, and maintenance of the electricity network, as well as delivering exceptional customer support. These services include strategic planning and the development of new electricity infrastructure to meet growing demand. The company facilitates connections for newly built properties to the grid and manages the integration of additional loads for existing properties to accommodate upgrades or increased energy requirements.

In line with supporting renewable energy adoption, the company processes applications for solar projects, ensuring compliance with technical and regulatory standards. It also handles various requests related to operational work on the electricity network, providing timely and effective solutions. Electrical design approvals are offered for new developments to ensure they align with safety and performance standards.

The company plays an active role in maintaining and upgrading customer infrastructure by conducting inspections, replacements, and relocations of electricity meters for existing properties. To enhance network reliability, it oversees both scheduled and emergency outage management, keeping customers informed of power disruptions and restoration timelines.

As part of its commitment to service quality, the company tests and certifies electrical technicians, issuing licenses to ensure a skilled workforce. It also manages a wide range of customer interactions by receiving and addressing requests, inquiries, and complaints related to network operations. Additionally, the company responds promptly to customer queries regarding electricity outages, ensuring transparent communication and support throughout the resolution process. The Figure 1 shows the authorized area for NEDC.

NEDC to achieve the above services, it set vision, mission and values which are:

- **Vision:** Nama Distribution company is a leading reference for electricity services excellence in the Region.
- **Mission:** Empower Oman through safe, reliable, sustainable, economic and customer focused electricity.
- **NEDC Value:** Care, Deliver and Do Better.



Figure 1: NEDCs Licenses Area

1.2. NEDC Key Statistical Data

The key statistical figures related to the existing electricity distribution network are enumerated in Table 1 below:

Table 1: NEDC key statistical data

Asset Type	Overhead line (All voltage levels)	Underground Cable (All voltage levels)	Distribution Substation (11/0.415 kV)	Primary Substation (33/11 kV)	Grid Station (220/132/33 kV)	Customer Number	Licensed Area
Unit	km	km	No.	No.	No.	No.	km ²
Dakhiliah	7,533.39	6,252.43	7,270	93	9	154,839	31,900
North Sharqiyah	7,274.35	3,774.66	5,234	48	6	92,491	21,136
South Sharqiyah	3,758.60	3,548.26	3,080	48	4	93,512	12,000
South Batinah	6,815.93	9,502.81	8,088	78	14	200,528	3,500
Al Wusta	3,114.54	2,014.07	1,727	49	4	18,665	79,700
North Batinah	6,207.46	7,640.27	2,236	110	14	179,962	12,500
Muscat	2,537	13,670.90	9,183	186	39	458,542	3,500
Dhahirah	4,801.93	3,119.37	3,367	41	6	69,631	37,000
Musandam	725.49	1,135.34	791	17	3	17,192	1,800
Buraymi	2,255.42	1,694.74	2,090	28	5	42,417	7,000
NEDC Total	45,024.12	52,352.85	43,066.00	698	104	1,327,779	210,036

1.3. Purpose of Statement

The information in the Distribution System Capability Statement (DSCS) is published annually to fulfil NEDC regulatory obligation under Condition 33 of its Distribution Licence (DL) and Distribution planning code 4.4 of the Oman Distribution Code.

This DSCS is intended to provide an understanding of NEDC's 33kV, 11kV and LV distribution system along with presenting NEDC's development plans for the 33kV and 11kV distribution system for the years 2025-2026. This statement includes power system data for the primary substation loads, overhead lines, cable circuits, transformers, switchgear, and capacitors which forms the NEDC distribution system and used in the preparation of distribution system models for the power system studies. The results of load flow, short circuit studies and system technical losses are presented thereby providing an assessment of the capability of the distribution system.

Implementation of the system development plans is necessary to meet future forecast demand growth, maintain and/or improve the capability in the distribution system to meet the system growth and to address the issues of actual or forecast non-compliance with the Distribution System Security Standard (DSSS). Implementation of these plans will enhance the available system capacity as well as potentially

increase the number of 33/11.5kV primary substations (PSS) providing enhanced opportunities for new and increased customer connections.

The impact of NEDC's forecast demand growth and distribution system development plans on the Transmission System, which is owned and operated by Oman Electricity Transmission Company (OETC), has been fully assessed in the development of NEDC's development plans. Where appropriate 33kV load transfers from one 132/33kV grid substation (GSS) to another are feasible they have been considered and where this option is not feasible; applications for additional 132/33kV GSS capacity have been submitted to OETC, resulting in OETC plans to construct and build additional 132/33kV GSS capacity within the NEDC licence area.

1.4. Structure of this DSCS

The following summarises the structure of this Distribution System Capability Statement:

- **Chapter 1 - Introduction:** An overview of the NEDC area, the main function, and the statement's purpose. Moreover, it presents the key statistical data of NEDC to date.
- **Chapter 2 - Planning philosophy and Practices:** This chapter presents the governing standard that NEDC follows in planning, designing, operating, and maintaining the network. And it illustrates the asset characteristic, configuration, selection, and details of asset data.
- **Chapter 3 - Planning Drivers:** this chapter provides the overall distribution system connectivity in each governorate with future indications projects per wilayat.
- **Chapter 4 - NEDC Distribution System:** provides a summary view of the distribution system, together with details of the 2024 demand profile along with projected demand forecast, CRT impact analysis of NEDC system, system constraints, a summary of the required technical power system analysis of the distribution system. Furthermore, this chapter presents the power flow results for NEDC networks by listing the study methodology and data considered. In addition, it shows the technical losses percentage.
- **Chapter 5 - Challenges and Opportunities within the System:** This chapter presents the future Low Carbon technologies that going to affect directly in the power system such as PV solar systems, Electric vehicles, and the ambition plan of Oman for zero carbon.
- **Chapter 6 - Investment Plan:** The future projects, Network Suitability for New Connections and system constraints are presented in section Six.

2. PLANNING PHILOSOPHIES AND PRACTICES

2.1. Governing Standard

NEDC has an operating philosophy that underlies the development of the distribution system at the three-voltage level 33, 11, and 0.415 kV and potentially would introduce new 66kV system for some of rural areas that mandate long distribution network. Furthermore, it ensures that the whole distribution system satisfies the following fundamental design criteria throughout the planning period:

- Sector Law Royal Decree 78/2004: Enabling legislation that established the Oman Electricity and Water Sectors. Article 90 obligates Distribution Companies to finance, operate, maintain, develop and expand the Distribution System safely and under the relevant performance and security standards.
- NEDC's license conditions 4, 32, and 33.
- Distribution Code Version 1.1 (April 2020).
- Grid Code Version 3.0 (August 2020).
- Oman Electrical Standard (OES) and international standards.
- Distribution System Security Standard (APSR letter 2008).
- Connection Statement Version 1 (October 2006).
- Electrical Safety Rules.

Copies of the above standards and codes are available on APSR's website (<https://apsr.om/en/home>). Moreover, the distribution system must also be capable of being operated, maintained, repaired, extended and replaced as necessary during its life without exceeding design levels of risk to the customers it serves.

2.2. System Characteristic

NEDC designs its electricity distribution system based on several technical characteristics to fulfil the requirements of the regulations and standards. System fundamental characteristics are described below:

2.2.1 System Parameters: NEDC will ensure that the Distribution System complies with the following technical, design, and operational criteria concerning the Distribution System at the Connection Site with a Distribution System User. System parameters are briefed in the following Table 2:

Table 2: System Parameter

No.	Parameter	Unit	Distribution System Voltage (KV)		
			LV	11	33
1	Nominal Voltage	kV	0.415	11	33
2	Rated Frequency	Hz	50	50	50
3	Short Circuit Level	kA	40	18.4 ¹	25 ²
4	Harmonic Level	%	2.5	2	2
5	Voltage fluctuations	%	3	3	3

¹ There are different short circuit level 25 kA and 31.5 kA based on Substation design requirements.

² There are different short circuit level 31.5 kA based on Substation design requirements.

2.2.2 Voltage regulation: The voltage on the 33 kV and 11 kV sides of Distribution transformers at Connection Sites with Distribution System Users shall typically be controlled within limits $\pm 6\%$ of the nominal value.

Table 3: Voltage Regulation

Nominal Voltage Level	Tolerance	
	+6%	-6%
33kV	34.98kV	31.02kV
11kV	11.66kV	10.34kV
415V	439.90V	390.10V
240V	254.40V	225.60V

2.2.3 Frequency Deviation: During normal operating conditions, the nominal System Frequency of the Transmission and Distribution Systems will be 50.00 Hz and usually will be controlled by Oman Electricity Transmission Company (OETC) between 49.95Hz and 50.05Hz. During exceptional steady-state conditions, Frequency deviations will not exceed 49.90Hz to 50.10Hz unless disturbed circumstances prevail. Under disturbed conditions, System Frequency could rise transiently to 51.50 Hz or fall to 48.00 Hz.

2.2.4 Voltage Waveform Quality: The maximum total levels of harmonic distortion on the Distribution System at 33 kV and 11 kV, from all sources under both normal, planned outage and fault outage conditions, shall not exceed a total harmonic distortion of 2.0 % with no individual harmonics greater than 1.5 % unless abnormal conditions prevail. At LV, the maximum levels of harmonic distortion from all sources shall not exceed a total harmonic distortion of 2.5 %.

The maximum negative phase sequence component of the phase voltage on the Distribution System should remain below 1.0 % unless abnormal conditions prevail. A maximum value of 2.0 % is permitted for phase unbalance.

2.2.5 Voltage Fluctuation: Voltage fluctuations arising from fluctuating Demands Connected at a Connection Point to the Distribution System shall not exceed 1.0% of the voltage level for step changes that may occur repetitively. Any large voltage excursions other than step changes may be allowed up to a level of 3.0%, provided this does not constitute a risk to the Distribution System or any Distribution System User.

2.2.6 Distribution System Security Standard (DSSS): After the approval of Distribution System Security Standards in November 2008, as shown in Table 4 below, NEDC is obliged to comply with the Planning requirements of Security Standards. Since NEDC's Distribution License grant, NEDC has started planning its distribution network to comply with simple planning principles to supply its customers with high-quality products.

Table 4: Distribution System Security Standards DSSS

Class	Demand Group	First Outage	Second Outage
A	Less than 2 MW	Repair Time	No Requirement
B	2MW to 6MW	3 Hours ³	No Requirement
C	6MW to 20MW	Within 15 minutes	Restoration time of planned outage
D	20MW to 100MW	Immediately	Restoration time of planned outage
E	Greater than 100MW	Immediately	Immediately, 2/3 of demand

According to the Security Class, a 33 kV feeder is considered not complying with the standards if, upon a fault on the feeder, the Demand Group cannot be supplied within the prescribed period. A portion of the feeder cannot be fed back, and the feeder is considered and classified as non-compliant.

For the 33/11 kV substations, two situations are of interest. In the first case, if two transformers are installed in a substation but the total load is greater than the capacity of one transformer, then the substation is considered non-compliant. The second situation is where only one transformer is installed, and there is no link to a nearby substation that can take the affected demand group, then the substation is considered non-compliant. It is worth mentioning that non-compliance is only during the summer period. For most of the year, many feeders and substations comply with the DSSS except the radial feeders, T-Offs, and substations with only one installed transformer. All investments in NEDC Network are to make all substations comply with DSSS.

2.3. System Configuration

2.3.1 33 kV system: The 33 kV System of NEDC serves a distribution role between the OETC and the 11 kV system as direct 132/11 kV transformation is also in use. The System consists mainly of 33 kV feeders, 33/11kV primary substations, and 33/0.415 kV transformers installed on some feeders where it is not feasible to develop an 11 kV network due to limited demand. The 33 kV feeders from the 132/33 kV grid stations supply the 33/11 kV primary substations.

Primary substations are of two types, namely indoor and outdoor. Indoor primary substations are mainly 2x10 MVA, 2x20 MVA and 3x20 MVA with 33 kV outdoor/indoor circuit breakers and 11 kV indoor switchgear panels. Indoor primary substations are proposed to be constructed during the coming years to supply highly growing areas. Outdoor primary substations are installed throughout the ten governorates of NEDC in urban and rural areas where demand usually is less than 6 MW. The regular

³ For 11kV networks in remote areas this restoration time may be extended by the time it reasonably takes for a repair crew to reach the area with the outage as long as the total restoration time will not exceed 6 hours.

practice is to supply each primary substation with two 33 kV feeders; each feeder feeds one transformer and serves as an alternative supply for the whole substation if the other feeder fails.

Along with the 33 kV feeders, Tees are used to connect primary substations. The entire network is interconnected, except in a few situations where radial feeders without interconnections with other feeders feed primary substations. The number of 33/11 kV substations and transformers in the System up to September 2024 is shown in Table 5.

Table 5: Number of 33/11 kV transformers

Power Transformer Size	Governorate										NEDC
	Muscat	Dhakliyah	Dhahirah	Wusta	North Sharqiyah	South Batinah	South Sharqiyah	North Batinah	Buraymi	Musandam	
1 MVA	1		2	4			2		1	5	15
2 MVA				1						1	2
3 MVA	7	7		16	8	1	2	6	2	7	56
5 MVA	4		10								14
6 MVA	49	81	29	21	61	61	40	50	18	7	417
10 MVA	10	8	11	12	2	3	9	13	5	4	77
15 MVA				1							1
16 MVA	16										16
20 MVA	331	98	37	28	32	86	44	157	24	8	845
31.5 MVA	2										2
40 MVA				1							1
Total	420	194	89	84	103	151	97	226	50	32	1446

The 33 kV indoor switchgear is a single bus bar, totally enclosed metal-clad type with withdrawable circuit breakers or metal-clad SF6 insulated with vacuum or SF6 circuit breakers. 11 kV and 33 kV current ratings of the bays are shown in Table 6.

Table 6: Current Ratings of Bus Bar, Bus-section, Transformer, and Feeder Bays

Rating ⁴	11 kV at Primary Substations	33 kV
Bus-bar	2000 A	2000A
Bus-Section	1200 A	1200A
Transformer	1200 A	600A
Feeder	400 A	600A

Most of NEDC's primary substations are standard two transformers with two separate 33 kV and 11 kV busbars. In some cases where demand is much less than the capacity of two transformers, which is expected in remote rural areas, primary substations with only one 33/11 kV transformer are installed. The 33 kV network is designed and will be developed to meet its customer's satisfaction and comply with the Distribution System Security Standards (DSSS).

⁴ There are special cases where the thermal rating may vary.

2.3.2 11 kV System: The main purpose of the 11 kV systems is to distribute electricity into and around local urban and rural areas in an economical, efficient, safe and secure manner while meeting customers' needs. The general design principle for configuring the distribution system is based on primary substations, indoor and outdoor, with mainly two transformers and 11 kV busbars, providing a continuous firm 11 kV supply.

The 11 kV feeders from the 33/11 kV indoor and outdoor primary substations are overhead lines or underground cable feeding the distribution transformers. 11 kV circuit breakers are provided at all indoor primary substations, whereas 11 kV Auto-Reclosers are provided at the outdoor primary substations. Regular practice is usual when connecting feeders from the same primary substation or different primary substations through Ring Main Units (RMU), Air Break Switches (ABS), and Open Jumpers.

These 11 kV feeders are generally operated as radial feeders, with the open point selected for ease of operational access to minimize customer minutes lost while considering the need to meet security requirements and reduce system losses and voltage drops.

Distribution substations are of two types, ground-mounted and pole-mounted. One transformer with a rated capacity of 500 kVA or higher is commonly used for ground-mounted distribution substations, whereas those transformers with ratings less than 500 kVA are installed on H-Pole structures. Both substations are fed directly from the 11 kV feeders with jumpers (Pole-Mounted) or through 11 kV cables (Ground-Mounted). Expulsion fuses protect both substations on the high voltage side, and HRC fuses on the low-tension side. However, Ground-mounted transformers connected through HFU are protected by HRC fuses of 125 A, 63 A and 31.5 A for 2000 kVA, 1000 kVA & 500 kVA, respectively.

NEDC has already started implementing two smaller ratings, 25 and 50 kVA, to minimize transformer losses arising from higher ratings for loads far away less than the capacity of the transformer. The number of distribution substations in the system up to September 2024 is shown in the below table.

Table 7: Number of distribution transformers

Distribution Transformer Size	Governorate										NEDC
	Muscat	Dhakliyah	Dhahirah	Wusta	North Sharqiyah	South Batinah	South Sharqiyah	North Batinah	Buraymi	Musandam	
16 KVA	2			1							1
25 KVA	2	59	3	1	23	7	7				38
50 KVA	20	135	42	5	426	86	129	94	44	4	788
100 KVA	569	2395	1340	764	2128	1386	779	1499	808	218	7582
200 KVA	241	492	315	129	458	745	229	641	205	87	2494
250 KVA	8										0
315 KVA	503	1588	943	121	937	1398	526	2281	295	44	5602
500 KVA	1174	949	321	352	644	2464	552	853	264	330	5459
630 KVA	1	1		3							3
750 KVA	2			2							2
800 KVA	3	1	11		1						1
1000 KVA	7557	1683	802	400	660	2163	800	1755	632	221	6631
1250 KVA	17			4		4				2	10
1500 KVA	18			1	2			21		4	28
1600 KVA	222	10	1	1		5	1	13			20
2000 KVA	1929	76	4	39	19	152	107	182	1	3	503
2500 KVA	35			3				6	3		12
NEDC Total	12303	7389	3782	1826	5298	8410	3130	7345	2252	913	29174

2.3.3 Low Voltage System: The main purpose of the LV distribution system is to distribute electricity in local urban or rural areas and deliver it to customers' LV entry points in an economical, efficient, safe and secure manner. The LV system will generally be developed as a network of taped radial mains supplied from a distribution substation near the load Centre.

NEDC's low-tension network is designed and will be developed to meet its customer's satisfaction and comply with the approved Distribution System Security Standards.

2.3.4 Small Scale Grid Connected Solar PV Systems: The minimum technical specifications and connection methodologies for installation of small-scale grid connected Solar PV systems within Oman are specified in the Technical and Connection Guidelines published by APSR in May 2017; these shall be adhered by PV system installers and users for PV system installations. Furthermore, other national & international standards, network codes, and other specific technical requirements of NEDC may apply to solar PV generating plants and therefore shall be complied with.

2.3.5 Electric Vehicles (EV) Charging Technical Requirements: In July 2023, APSR published the EV Charging Technical Requirements Guidelines. The guidelines include the required technical specifications and connection methodologies for installation of EV charging within Oman. NEDC is in process of setting up the code of practice and the policy to be followed for EV applications.

2.4. Selection of Asset

The choice of network assets suitable to connect a specific demand is subject to many factors, including the following:

- Geographical location.
- Size and nature of the demand.
- Available network voltage level within the vicinity of the demand area.
- Spread of demand distribution (load density).

Based on NEDC technical specifications, standards, and regulations, the size and rating of network assets have been determined and can be summarized network common assets as per below Table 8:

Table 8: Standard Substation Size and Rating

Voltage Level (kV)	Equipment	Size/Type
33	Over Headline ACSR Conductor	200 Sq.mm (panther)
	Under Ground XLPE Insulated Copper Cable	3C X 300 Sq.mm
	Power Transformer	20 MVA
		16 MVA
		10 MVA
		6 MVA
		5 MVA
		3 MVA
		1 MVA
	Switchgear	SF6 GIS
		AIS

Voltage Level (kV)	Equipment	Size/Type
11	Over Headline ACSR Conductor	150 Sq.mm (wolf)
		100 Sq.mm (dog)
	Under Ground XLPE Insulated Copper Cable	3C X 240 Sq.mm
		3C X 185 Sq.mm
	Distribution Transformer	2000 KVA
		1000 KVA
		500 kVA
		315 kVA
		200 kVA
		100 kVA
		50 kVA
		25 kVA
	Switchgear	Oil RMU
		SF6 RMU
0.415	Over Headline XLPE Covered Aluminium Conductor	120 Sq.mm
		70 Sq.mm
	Under Ground XLPE Insulated Copper Cable	4C X 240 Sq.mm
		4C X 185 Sq.mm
		4C X 120 Sq.mm

2.5. Details Asset Data

NEDC detailed assets list and evolution in Appendixes B.1, B.2, B.3, B.4 and B.5, while the below link presents the geographical maps of the 10 governorates under NEDC service area showing the locations of Interface points with OETC, NEDC primary substations, 11 kV feeders, and distribution transformers.

Geographical map link:

<https://mzgportal.mzec.co.om/portal/apps/webappviewer/index.html?id=dfb78b59fc294e3082ed3c213ee360e4⁵>

⁵ The Username and password to be provided upon request.

3. PLANNING DRIVERS

3.1. Background

NEDC's electricity distribution system serves around 1,327,779 customers as per end of September 2024 cover Muscat, South Batinah, Dakhilah, North Al Sharqiyah, South Al Sharqiyah, Al Wusta, North Batinah, Musandam, Al Buraymi and Al Dhahirah Governorates. The characteristics of the distribution system within the NEDC licence areas differ mainly because of three major parameters:

1. The load density.
2. The type and usage pattern of the customer.
3. The majority type of feeder circuits (i.e., overhead, or underground).

The 2024 maximum demand recorded for NEDC MIS system was 7,326.6 MW⁶ (on Thursday – 26th June 2024 at 14:43 Hrs) and Musandam Area was 100.87 MW⁷ on Sunday 23rd June 2024 at 13:16. For Al Wusta Area the Non-coincident peak was 137.33 MW.

As of 2024 peak period, the total existing number of 132/33kV grid substations is 104, 33/11.5kV primary substations connected to the NEDC distribution system is 698 with a Total Firm Capacity of 11,400.5 MVA. The tables identifying each Primary Substation capacity and current demand can be found in Appendix B.

The sections remaining from this chapter provide the following:

1. A summary of the individual Governorate built up and the planning drivers for each Governorate.
2. It also provides an overview of the complete current NEDC system connectivity including governorate classification of the primary substation.

⁶ MIS Transmission peak excluding of transmission technical losses and Grid Stations auxiliary load

⁷ Including 7 MW of isolated Madha load

3.2. Muscat Governorate

The Muscat Governorate includes Wilayat Muscat, Muttrah, Amerat, Quriyat, Bousher and Seeb. The number of customers served in the Muscat Governorate region is 458,542 which is approximately 35% of the total customer population within NEDC. **Error! Reference source not found.** shows all existing primary substations with their installed and firm capacity within Muscat Governorate.

3.2.1. Wilayat Muscat

Wilayat Muscat is considered as one of the saturated areas within Muscat Governorate except Yitti Area. The Yitti Tourism Development is one of the major projects. Moreover, the plan is to construct two numbers of PSSs; one is in energization stage, and the other one is in the planning Stage.

3.2.2. Wilayat Muttrah

Wilayat Muttrah has circa zero growth for the last two years. There is one potential project for Muttrah Development as bulk load customer, and it is still within the planning stage.

3.2.3. Wilayat Amerat

Amerat has seen the highest demand growth for the last 5 years within Muscat Governorate validating for a significant demand growth forecasted for the current planning horizon.

3.2.4. Wilayat Quriyat

Quriyat has an average of 2.6% load growth for the next three years and there is no major project in the area.

3.2.5. Wilayat Bousher

Bousher Height Smart City is one of the biggest projects in Wilayat Bousher. As load demand the area has low growth with an average of 2.1%.

3.2.6. Wilayat Seeb

Seeb has experienced increasing demand over the past five years within Muscat Governorate specially Mabelah area. Moreover, Mabelah area is one of the largest commercial and residential areas. Adding the new development for Sultan Haitham City.

Table 9: Muscat Governorate - Grid and Primary Substations Connectivity

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Falaj[G23] GSS			
Falaj	P178	2 x 16	16
Darsait	P018	2 x 20	20
Muttrah Store	P085	2 x 20	20
Jibrooh	P041	3 x 20	40
Sea Port	P086	2 x 6	6

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
P.D.O	P144	3 x 20	40
Mutrah[G21] GSS			
C.B.D	P173	2x10 and 1x16	20
Ruwi Office	P108	2 x 20	20
Bait Al Falaj	P142	3 x 20	40
Riyam	P099	2 x 20	20
Wadi Al Kabir[G19] - A GSS			
M.B.D South	P075	2 x 20	20
Qasr Al Alam	P090	2 x 20	20
Waljah	P130	2 x 20	20
Sidab	P119	2 x 6	6
Wadi Al Kabir Workshop	P126	2 x 6	6
Wadi Al Kabir Housing	P127	1 x 6	-
Ali Shihani	P125	2 x 20	20
Majlis Oman	P066	2 x 20	20
Wadi Al Kabir[G19] - B GSS			
Ruwi Valley	P174	2 x 20	20
Ruwi Market	P076	2 x 20	20
Old Airport	P107	2 x 20	20
Wadi Al Kabir Height	P128	2 x 20	20
Wadi Adai[G22] GSS			
Amerat 1	P005	2 x 16	16
Al Bustan Palace	P017	2 x 16	16
Al Hamryah	P035	2 x 20	20
Wadi Adai	P175	2 x 20	20
Wattaya	P131	2 x 20	20
Khoula Hospital	P132	3 x 20	40
Al Mahaj	P136	2 x 6	6
Jahlout[G03] GSS			
Sawaqim 1	P112	2 x 6	6
Sawaqim 2	P113	1 x 6	0
Tunis Heium	P137	1 x 6	0
Jahlout	P040	2 x 6	6
Siya	P120	2 x 6	6
Barr Al Jissah	P044	2 x 20	20
Amerat Jahlut [Al Masarat]	P068	2 x 10	10
Al Hajir	P031	2 x 20	20
Wadi Al Mayh	P129	1 x 3	0
Hussan Yiti	P169	2 x 6	6
ROP Al Saleel	P162	2 x 6	6
Al Atkiya	P182	1 x 6	0

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Water Pumping	P193	2 x 6	6
Arqi	P121	1 x 3	0
Yiti[G08] GSS			
Al Khairan	P045	1 x 6 + 1 x 3	3
Yenket	P133	1 x 1 + 1 x 3	1
Saraya Bander	P145	3 x 20	40
Jabal Al Sifah	P159	3 x 20	40
Yiti	P134	2 x 3	3
Muscat Yankit	P199	1 x 6	0
Al Salam Yiti	P135	1 x 6	0
Quriyat[G05] GSS			
Quriyat	P091	2 x 20	20
Al Shahbari	P092	2 x 20	20
Dhagmar 1	P021	4 x 6	18
Debah	P114	1 x 6	0
Dhabab	P019	2 x 6	6
Hail Al Ghaf	P036	2 x 6	6
Al Mazara	P074	2 x 6	6
Wadi Al Arbyeen	P124	1 x 6	0
Street Light	P020	1 x 6	0
RoyalCamp	P170	1 x 3	-
Amerat[G10] - A GSS			
Post Office	P150	3 x 20	40
Amerat Heights	P152	3 x 20	40
Amerat 3	P179	3 x 20	40
Amerat[G10] - B GSS			
Al Nahdah	P006	3 x 20	40
Seih Dhab	P118	2 x 20	20
Madinat Al Nahdah	P065	2 x 20	20
Al Jufaina	P194	1 x 6	0
Amerat Amerat [Amerat 4]	P180	3 x 20	40
Ghubrah 2[G09] GSS			
Azaibah North 2	P012	2 x 20	20
Ghubrah North 2	P149	3 x 20	40
Ghubrah North 1	P023	3 x 20	40
Diplomatic City	P022	3 x 20	40
Ghubrah GPS	P166	2 x 16	16
MSQ[GP06] - A GSS			
Al Khuwair North	P054	3 x 20	40
MSQ Grid	GP06	2 x 20	20
Royal Office	P097	2 x 20	20

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Intercontinental	P109	2 x 20	20
Information City 2	P038	1 x 5	-
Sarooj -Shati Al Qurum	P110	2 x 20	20
MSQ[GP06] - B GSS			
Al Khuwair 25	P053	2 x 20	20
Al Khuwair School	P146	3 x 20	40
MSQ 1	P083	2 x 20	20
ROP -Shati Al Qurum	P111	2 x 20	20
Digital TV Studio	P039	2 x 20	20
Qurum[G06] GSS			
Information City 1	P037	2 x 20	20
Qurum 1	P093	2 x 20	20
Qurum 2	P094	2 x 20	20
Lulai	P095	2 x 20	20
MSQ 2	P155	3 x 20	40
Rabiat Al Qurum	P096	2 x 20	20
Bousher [GP02] - A GSS			
Bousher Grid	GP02	2 x 20	20
Al Khuwair South	P052	3 x 20	40
Al Khuwair 17/1	P050	2 x 20	20
Bousher [GP02] - B GSS			
Azaibah North 1	P011	2 x 20	20
Bousher 2	P163	3 x 20	40
Holiday Inn	P051	3 x 20	40
Al Muna	P084	2 x 20	20
Tilal Al Khuwair	P055	3 x 20	40
Ghala Heights[G24] -A GSS			
Al Ansab 1	P007	2 x 20	20
Azaibah South 1-A	P014	2 x 20	20
Ghubrah South 1	P026	3 x 20	40
Ghala Heights[G24] -B GSS			
Mall Of Oman	P171	3 x 20	40
Azaibah South 1-B	P147	3 x 20	40
Royal Hospital	P024	3 x 20	40
Ghala[G11] - A GSS			
ROP Hospital	P172	3 x 20	40
Oman Exhibition	P165	3 x 20	40
Ghala 1	P015	3 x 20	40
MOD Al Ansab	P167	2 x 10	10
Al Ansab STP	P009	2 x 20	20
Ghala[G11] - B GSS			

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Ghala 2	P156	3 x 20	40
Al Ansab 2	P008	2 x 20	20
Airport Heights [G01] - A GSS			
Airport Height 2	P002	2 x 20	20
Airport Height 1	P001	2 x 20	20
Airport Height 5	P151	2 x 20	20
MOD Technical College	P081	2 x 20	20
Airport Height 3	P003	2 x 20	20
Airport Height 4	P004	2 x 20	20
Airport Heights [G01] - B GSS			
Azaibah North 3	P013	3 x 20	40
Seeb Airport Heights	P195	2 x 20	20
Rusail Industry[G13]-A GSS			
SQU 1	P122	3 x 16	32
SQU 2	P123	2 x 16	16
Rusail Industrial 1	P103	2 x 16	16
Rusail Industrial 2	P104	2 x 20	20
Al Jifnain	P042	1 x 6	0
Al Jifnain 2	P196	1 x 6	0
Seeb Muaskar Murtafiah [AFH]	P204	2 x 20	20
Cement Housing	P088	2 x 5	5
Rusail Industry[G13]-B GSS			
Rusail Industrial 3	P105	2 x 20	20
Rusail Housing	P056	2 x 20	20
Rusail08(KOM)	P164	3 x 20	40
ROP Al Khoudh	P161	2 x 20	20
Rusail Private Factory	P106	2 x 20	20
Rusail Industrial 4	P158	3 x 20	40
SQU 3	P160	3 x 20	40
Misfah[G04] GSS			
Al Misfah	P080	3 x 20	40
Al Awabi	P139	3 x 20	40
Orpic	P192	2 x 6	6
Cement Factory 1	P079	2 x 31.5 + 3x20	91.5
Barka[G02] GSS			
Manomah	P067	2 x 20	20
Mabelah [GP04] GSS			
Mabelah Grid	GP04	2 x 20	20
Sur Al Hadid	P116	3 x 20	40
Botanic Garden	P016	2 x 20	20
ROP Dog Kennel	P183	2 x 6	6

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Mabelah STP	P140	2 x 10	10
Al'Salam [G12] - A GSS			
Mabelah C	P064	3 x 20	40
Mabelah South PH-4	P062	3 x 20	40
PalmMall	P168	3 x 20	40
Al'Salam [G12] - B GSS			
Mabelah Shabiya	P060	3 x 20	40
Seeb Mabelah South [PH-6]	P185	3 x 20	40
Seeb Mabelah South [Pumping]	P198	2 x 20	20
Seeb Mabelah South	P061	3 x 20	40
Mabelah Industrial[G26] - A GSS			
Old Mabelah	P059	2 x 20	20
Palace Communication	P033	1 x 6	0
RGO Halban Camp	P034	1 x 5	0
Mabelah South 9	P184	3 x 20	40
Mabelah Industrial[G26] - B GSS			
Mabelah South PH-8	P157	3 x 20	40
Mabelah South PH-7	P141	3 x 20	40
Mabelah A	P063	3 x 20	40
Seeb [GP08] - A GSS			
Al Khoudh Shabiya [A]	P046	3x20	40
Wadi Bahayis (RGO)	P098	2 x 20	20
Wadi Al Aresh	P115	2 x 20	20
Wadi Al Lawami	P117	3 x 20	40
Seeb [GP08] - B GSS			
Seeb Grid	GP08	2 x 20	20
Sultan School	P029	2 x 20	20
Al Hail South 2	P153	3 x 20	40
New Al Khoudh	P047	2 x 20	20
Boulevard Mall	P186	3 x 20	40
Mawaleh South [GP05] - A GSS			
Al Hail North 2	P028	2 x 20	20
Mawaleh South Grid	GP05	2 x 20	20
Mawaleh C	P072	2 x 20	20
Rusail B	P101	2 x 10	10
Royal Flight	P100	2 x 20	20
Mawaleh South [GP05] - B GSS			
Mawaleh B	P071	3 x 20	40
Al Khoudh PH-6	P049	2 x 20	20
Al Hail South 1	P030	2 x 20	20
Seeb Muaskar Murtafiah [MOD]	P203	3 x 20	40

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Mawaleh South 5	P148	3 x 20	40
Al Khoudh[G25]- A GSS			
Mawaleh A	P070	3 x 20	40
Al Khoudh PH-3	P048	2 x 20	20
Seeb Muaskar Murtafiah [Al Bander]	P197	3 x 20	40
Seeb Khoudh [Al Khoudh Shabiya (B)]	P187	2 x 20	20
Al Khoudh[G25]- B GSS			
Al Khoudh PH-7	P154	3 x 20	40
Mawaleh North [GP01] GSS			
Al Hail North 1	P027	3 x 20	40
Mawaleh North	P069	3x20	40
Mawaleh North Grid	GP01	3 x 20	40
City Centre	P073	2 x 20	20
Dhagmar [GP11] GSS	It is 132/11 kV Grid Station. So, no PSS is connected in this Grid.		

3.3. South Al Batinah Governorate

South Batinah Governorate and Suawiq Area includes Barka, Musanah, Nakhal, Rustaq, Wadi Mawel, and Awabi. The number of customers served in South Batinah Governorate is 200,528. There are 14 Grid stations (132/33 & 220/33 kV), 78 primary substations (33/11 kV) are feeding the South Al Batinah governorate. Barka area has the largest growth among other areas in South Batinah governorate and there are many NEDC Investments in the area to cover the need of load demand. One of the major projects is new primary substation in Khazaen Economic City which is part of Oman Vision 2020-2040. The below table provides a list of primary substations in the South Al Batinah Governorate and Suawiq Area. Table 10 shows all existing primary substations with their installed and firm capacity within South Al Batinah Governorate.

Table 10 : South Al Batinah Governorate - Grid and Primary Substations Connectivity

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Rustaq Grid			
Dahas	DAHASP01B	2x20	20
Hazim	HAZIMP01B	2x20	20
Hoqain	HOQAINP01B	2x6	6
Iraqi	IRAQIP01B	2x20	20
Kahaf	KAHAFP01B	2x6	6
Maksofah	MAKSOFAHP01B	2x6	6
Marji	MARJIP01B	2x6	6
Musanah Air Base-2	MSNABASEP02B	1x3	0
Rustaq Grid	RSQGRIDP01B	2x20	20

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Rustaq Hospital	RSQHSPTLP01B	2x6	6
Rustaq Ind.	RSQINDP01B	2x6	6
Rustaq Roual Camp	RSQRCAMPP01B	1x6	0
Rustaq	RUSTAQP01B	2x20	20
Tabaqah	TABAQAH01B	1x6	0
Tawi Bado	TAWIBADOP01B	1x6	0
Tikhah	TIKHAHP01B	2x6	6
Wadi Sahtan	WDISAHTNP01B	2x6	6
Wishayl	WISHAYLP01B	2x20	20
Rustaq Al Bashair	RSQBSHIRP01B	2x20	20
Wadi Bani Auf Grid			
Awabi	AWABIP01B	2x20	20
Kasfah	KASFAHP01B	2x20	20
Wadi Bani Awf	WDIBAWFP01B	2x20	20
Wadi Bani Kharous	WDIBKROSP01B	2x6	6
Nakhal Grid			
Abyad	ABYADP01B	3x6	12
Afi	AFIP01B	2x20	20
Halban	HALBANP01B	1x6	0
Modern Poultry Farms	MODERNPFP01B	2x6	6
Nakhal	NAKHALP01B	2x20	20
Khazaen PSS	KHAZAENP02B	3x6	12
Subaikha Temp	SUBAIKHAP01B	1x6	0
Taww	TAWWP01B	2x6	6
TurKi	TURKIP01B	1x6	0
Tuwayah	TUWAYAHP01B	1x6	0
Wadi Mstal	WDIMSTALP01B	2x6	6
Wadi Maawil ROP	WDIMLROPP01B	2x6	6
Barka Grid			
Aman Camp	AMANCAMPP01B	2x20	20
Filayj Village PSS	FLAYJVLGP01B	1x6	0
Filayj Ind Area-1 Temp	FLAYJINDP01B	1x6	0
Filayj Ind Area-2 Temp	FLAYJINDP02B	1x6	0
German University	GERMNUNIP01B	2x20	20
Madeena Logistics	MDENALOGP01B	1x6	0
Rumays	RUMAYSP01B	2x20	20

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Rumays Tmp	RUMAYSP01B	1x6	0
Sandan	SANDANP01B	3x6	12
Shakakit	SHAKAKITP01B	3x20	40
Sultan Special Force	SSFORCEP01B	2x6	6
Barka-3 PS			
Barka IWP 1	BARIWPP01B	2x20	20
Barka IWP 2	BARIWPP02B	2x20	20
Barka-5 IWP	BARIWPP03B	2x20	20
Hay Asim Temp	N/A	1x6	0
Madinat Barka-A			
Barka Town	BARTOWNP01B	3x20	40
Salahah	SALAHHP01B	2x20	20
Saqsuq	SAQSUQP01B	3x20	40
Sumhan North	SUMHANNRP01B	2x20	20
Madinat Barka-B			
Aqir	AQIRP01B	2x20	20
Atyab Bakery	ATYBBKRYP01B	2x6	6
Haram	HARAMP01B	3x20	40
Khuwyrat	KHUWYRATP01B	3x20	40
Sumhan South	SUMHANSUP01B	2x20	20
MIS			
Hatheeb	HATHEEBP01B	2x20	20
Khabah	KHABAHP01B	3x20	40
Said Bin Sultan Naval Base	SBSNBASEP01B	2x20	20
Tharmad Temp-1	THARMADP02B	2x6	6
Tharmad Temp-2	THARMADP03B	1x6	0
Widam Sahil	WDMSAHILP01B	2x10	10
Widam Sahil Temp	WDMSAHILP02B	1x6	0
Muladah-A			
Musanaah Air Base	MSNABASEP01B	2x10	10
Musanaah Ind Area	MSNINDP01B	2x20	20
Muladah	MULADHP01B	3x20	40
Musanaah	MUSANAHP01B	2x20	20
Saih Muladah	SIHMLDHP01B	1x6	0
Sport City	SPRTCITYP01B	2x20	20
Tharmad	THARMADP01B	1x6 + 1x10	6

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Muladah-B			
Maghsar South	MAGHSRSUP01B	2x6	6
Maharah	MAHARAHP01B	3x20	40
Uwayd	UWAYDP01B	3x20	40
Jamma Temp	JAMMAP02B	1x6	0
AL Hazam Water	HZMPUMPSP01B	2x6	6
Blue City			
Barka New	BARNEWP01B	2x20	20
Barka Sahil	BARSAHILP01B	3x20	40
Billah	BILLAHP01B	2x20	20
Billah Wadi	BILAHWDIP01B	1x6	0
Blue City	BLUECITYP01B	2x6	6
Hay Sharq Temp	HAYSHARQP02B	1x6	0
Hufri	HUFRIP01B	2x20	20
Musanaah Sahil	MSNSAHILP01B	3x20	40

3.4. Al Dakhiliah Governorate

Al Dakhiliah Governorate includes Sumail, Izki, Nizwa, Bahla, BidBid, Manah, Hamra, Jabal Akhader and Adam. The number of customers served in the Al Dakhiliah Governorate region is 154,839. There are 9⁸ Grid stations (132/33 & 220/33 kV) and 93 primary substations (33/11 kV) are feeding the governorate. Table 11 below provides list of primary substations in Al Dakhiliah Governorate.

Table 11: Al Dakhiliah Governorate- Grid and Primary Substations Connectivity

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Adam Grid			
Adam Grid	ADMGRIDP01B	2x20	20
Zoubar	ZOUBARP01B	2x20	20
Adam Air Base	ADMABASEP01B	2x10	10
Adam Bashair	ADMBSHIRP01B	2x6	6
Mitan	MITANP01B	2x6	6
Bahla Grid			
Bahla Grid	BHLGRIDP01B	2x20	20
Bilad Sayt	BLADSAYTP01B	2x6	6

⁸ The GSS counted as number in Muscat Governorate

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Hamra	HAMRAP01B	2x20	20
Hamra 2	HAMRAP02B	3x20	40
Tanuf	TANUFP01B	2x6	6
Mamurah	MAMORAH01B	2x20	20
Buwaydah	BUWAYDAHP01B	2x6	6
Sint	SINTP01B	2x3	3
Jabrin Grid			
Bidoou	BIDOOUP01B	2x20	20
Bisya	BISYAP01B	2x6	6
Ghafat	GHAFATP01B	2x20	20
Habbi	HABBIP01B	2x20	20
Jabrin	JABRINP01B	2x20	20
New Bahla	NEWBHLP01B	2x20	20
Wadi Qurayat	WDIQRYP01B	2x20	20
ROP Academy 2	ROPACDMYP02B	2x20	20
Saih Shamakhat	SIHSHMKTP01B	1x3	0
ROP College	ROPCOLEGP01B	3x20	40
Nizwa Grid			
Farq	FARQP01B	3x20	40
Hisn Shmoukh	HSNSHMUKP01B	3x20	40
Izz	IZZP01B	2x20	20
Hay Al Tourath	HAYTRATHP01B	2x20	20
Karsha	KARSHAP01B	3x6	12
Maara Temp	MAARAP01B	1x6	0
Mamad	MAMADP01B	1x6	0
Manah	MANAHP01B	2x20	20
Oman Across Age Museum	OMAAMUSMP01B	2x20	20
Oman Across Age Museum Temp	OMAAMUSMP02B	1x6	0
Nizwa Grid	NZWGRIDP01B	2x20	20
Nizwa Ind Area	NZWINDP01B	2x20	20
Nizwa RDC Temp	NZWRDCP02B	1x3	0
Nizwa Stadium	NZWSTDUMP01B	3x6	12
Nizwa University 2	NZWUNIP02B	2x20	20
ROP Academy	ROPACDMYP01B	3x6	12
ROP Cadet Academy Temp	ROPCADETP02B	1x6	0
Taymsa	TAYMSAP01B	2x20	20

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Madinat Nizwa Grid			
Kamah	KAMAHP01B	2x20	20
Marfa Daris	MRFADARSP01B	3x6	12
Hay Ayn	HAYAYNP01B	3x6	12
Madinat Nizwa	MDINTNZWP01B	3x20	40
Nizwa Town	NZWTOWNP01B	2x20	20
Izki Grid			
Afiyah	AFIYAHP01B	2x20	20
Birkat Mawz	BRKTMWZP01B	2x6	6
Birkat Mawz 2	BRKTMWZP02B	2x20	20
Humaydah	HUMAYDAHP01B	3x6	12
Izki Grid	IZKGRIDP01B	2x20	20
Jabal Akhdar	JBLAKDARP01B	2x6	6
Jabal Akhdar 2	JBLAKDARP02B	2x20	20
Nizwa ROP	NZWROPP01B	2x6	6
Nizwa University	NZWUNIP01B	3x6	12
Wadi Maydin	WDIMAYDNP01B	1x6	0
Sayma	SAYMAP01B	2x6	6
Sumrah	SUMRAHP01B	3x6	12
Wadi Mahram	WDIMAHMRP01B	2x6	6
Wusad	WUSADP01B	2x6	6
New Izki Grid			
Aqil	AQILP01B	2x6	6
Izki Heights	IZKHIGHTP01B	3x20	40
MOD Shafa	MODSHAFAP01B	1x20	0
Qalat Awamir	QLTAWAMRP01B	2x20	20
Samail A Grid			
Heel	HEELP01B	3x20	40
Hub Water Pump	HUBWPUMPP01B	2x6	6
Samail	SAMAILP01B	3x20	40
Jaylah	JAYLAHP01B	1x6	0
Manal Water Pump	MANALWPP01B	2x6	6
Saih Rasiyat	SIHRASYTP01B	1x3	0
Samail B Grid			
Bidbid	BIDBIDP01B	2x6	6
Central Prison	CNTPRSONP01B	2x20	20

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Fanja Water Pump	FANJAWPP01B	3x6	12
Fayha	FAYHAP01B	2x6	6
Hassas	HASSASP01B	2x20	20
Hassas 2	HASSASP02B	2x6	6
Khubar	KHUBARP01B	3x6	12
MOD Bidbid	MODBIDP01B	1x6	0
Multaqa Crusher Temp	MULCRSHRP01B	1x3	0
Fanja	FANJAP01B	2x20	20
OMPC	OMPCP01B	2x20	20
Saih Maydin	SIHMAYDNP01B	2x20	20
Sumail Ind Zone 1	SMLINDP01B	3x20	40
Sumail Ind Zone 2	SMLINDP02B	2x20	20
Stadly Temp	STADLYP01B	1x6	0
Surur	SURURP01B	2x6	6
Wadi Saygani	WDISYGNIP01B	3x6	12
Hub Water Pump 2	NEWAINP01B	2x10	10
Fanja Water Pump 2 (New Hamem)	NEWHAMEMP01B	2x20	20
Ain Water Pump	NEWHOUBP01B	2x10	10
Rusail Ind Grid⁹			
Fanja 2	FANJAP02B	2x20	20
Saih Ahmer	SIHAHMERP01B	2x6	6

3.5. North Al Sharqiyah Governorate

The North Al Sharqiyah Governorate includes Mudhaibi, Ibra, Dima Wa Taiyyin, Wadi Bani Khalid, Qabil and Bidiyah. The number of customers served in the North Al Sharqiyah Governorate region is 92,491. There are 6 Grid Station (132/33 & 220/33 kV) and 48 primary substations (33/11 kV) are feeding the governorate. Table 12 below provides a list of primary substations in North Al Sharqiyah Governorate.

Table 12 :North Al Sharqiyah Areas – Power Plant, Grid, PDO and Primary Substations Connectivity

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Samad Grid			
Samad	SAMADP01B	2x20	20
Samad 2	SAMADP02B	2x20	20
Khadra Bani Dafa 2	KDRABDFAP02B	2x20	20

⁹ The GSS counted as number in Muscat Governorate

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Mudhaibi Grid			
Aflaj	AFLAJ01B	3x6	12
Hadeetha	-	3x6	12
Khadra Bani Dafa	KDRABDFAP01B	3x6	12
Khashbah	KHASHBAHP01B	3x6	12
Lizq	LIZQP01B	3x6	12
Mudhaibi Grid	MDBGRIDP01B	2x20	20
Saih Al Nama	SIHNAMEP01B	2x20	20
Mudhaibi Royal Camp PSS	MDBRCAMPP01B	1x3	0
Sinaw Grid			
Jaza	JAZAP01B	3x3	6
Quwayaah	QUWAYAAHP01B	2x6	6
Sinaw	SINAWP01B	2x20	20
Sinaw 2	SINAWP02B	2x20	20
Sinaw 3	SINAWP03B	3x20	40
Uyun	UYUNP01B	3x6	12
Zain Poultry Farms	ZAINPFP01B	1x6	0
Mudhairib Grid			
Dhabahah	DHABAAHP01B	1x6	6
MOD Ibra	MODIBAP01B	1x6	0
Feshgah	FESHGAHP01B	1x6 + 1x3	3
Masrun 2	MASRUNP02B	2x6	6
Hayal	HAYALP01B	2x6	6
Ibra ROP	IBAROPP01B	2x6	6
Ibra Hospital	IBAHSP01B	2x10	10
Maghsar	MAGHSARP01B	2x3	3
Masrun	MASRUNP01B	2x6	6
Mudhairib Grid	MDRBGRIDP01B	2x20	20
Shanah	SHANAHP01B	1x3	0
Sooqah	SOOQAHP01B	2x6	6
Wadi Nam	WDINAMP01B	3x6	12
Ibra Grid			
Ghayadah	GHAYADAHP01B	3x6	12
Ghubbrat Tam	GBRATTAMP01B	2x6	6
Hajer	HAJERP01B	2x6	6
Haymah	HAYMAHP01B	2x6	6
Ibra 1	IBRAP01B	2x20	20

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Ibra 2	IBRAP02B	2x20	20
Khanadiq	KHANADIQP01B	2x6	6
Sharqiya University	SHARQUNIP01B	2x6	6
Wadi Tayin	WDITAYINP01B	2x20	20
Yahmadi	YAHMADIP01B	2x6	6
Yahmadi 2	YAHMADIP02B	2x20	20
Bidiyah Grid			
Liwariyah	LIWARIYHP01B	2x6	6
Mintrib	MINTRIBP01B	3x20	40
Shariq	SHARIQP01B	2x20	20
Tawi Salim	TWISALIMP01B	2x6	6
Wasil	WASILP01B	2x6	6
Wadi Bani Khalid	WDIBKHLDP01B	3x6	12

3.6. South Al Sharqiyah Governorate

The South Al Sharqiyah Governorate includes Sur, Jalan Bani Bu Hassan, Kamil wa Wafi, Musirh and Jalan Bani Bu Ali. The number of customers served in the North Al Sharqiyah Governorate region is 93,512. There are 4 Grid Station (132/33 & 220/33 kV) and 48 primary substations (33/11 kV) are feeding the governorate. Jalan Bani Bu Ali and Jalan Bani Bu Hassan areas have the highest growth in the governorate, two 2x20 MVA primary substations are in commission stage and two 3x20 MVA primary substation are in design & survey stage. Table 13 provides a list of existing primary substations in South Al Sharqiyah Governorate.

Table 13:South Al Sharqiyah Areas – Power Plant, Grid, PDO and Primary Substations Connectivity

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Sur Grid			
Ayjah	AYJAHP01B	3x6	12
Filayj Water Pump	FILAYJWPP01B	2x6	6
Hay Sharooq	HAYSHROQP01B	2x10	10
Jenah	JENAHP01B	2x10	10
MOD Sur	MODSURP01B	1x6	0
Musfayyah	MUSFAYAHP01B	3x20	40
Qalhat	QALHATP01B	1x6	0
Qawda	QAWDAP01B	1x1	0
Shariya	SHARIYAP01B	2x20	20
Sur Filayj	SURFLAYJP01B	1x6 + 1x6	6
Sur Grid	SURGRIDP01B	2x20	20

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Sur Ind Area	SURINDP01B	2x20	20
Sur IWP	SURIWPP01B	2x20	20
Sur IWP 2	SURIWPP02B	2x20	20
Sur ROP	SURROPP01B	3x6	12
Tiwi	TIWIP01B	2x6	6
Ayjah Grid			
Ayjah Heights	AYJHIGHTP01B	2x20	20
Ras Had	RASHADP01B	2x6	6
Shamah	SHAMAH01B	1x1	0
Shiyaa	SHIYAAP01B	1x6	0
Skaykrah	SKAYKRAHP01B	3x20	40
Sur Hospital	SURHSPTLP01B	2x10	10
Sur Stadium	SURSTDUMP01B	2x20	20
Sur Town	SURTOWNP01B	2x20	20
TV Heights	TVHEIGHTP01B	2x6	6
Diar Ras Had	DIRASHADP01B	2x20	20
JBB Ali Grid			
Ashkharah	ASHKHARHP01B	2x20	20
Asilah IWP	ASILAIWPP01B	2x20	20
Asilah IWP Temp	ASILAIWPP02B	2x6	6
BBC	BBCP01B	1x10	0
JBB Ali Grid	JBAGRIDP01B	2x20	20
JBB Ali Royal Camp	JBARCAMP01B	1x3	0
JBB Ali	JBBALIP01B	3x20	40
JBB Ali 2 Temp	JBBALIP11B	2x6	6
Qarhah Temp	QARHAHP01B	1x6	0
Ras Had Airport	RASHADAPP01B	2x10	10
Rumaylah	RUMAYLAHP01B	1x6	0
Saih Ramath	SIHRAMTHP01B	3x6	12
Saih Ula	SIHULAP01B	3x20	40
Wadi Batha Temp	WDIBATHAP01B	1x3	0
Wadi Sal	WDISALP01B	3x6	12
JBB Hassan Grid			
JBB Hassan	JBBHASANP01B	2x20	20
Hadri Bilad	HDRIBLADP01B	2x6	6
JBB Hassan 2	JBBHASANP02B	3x20	40
Kamil	KAMILP01B	3x20	40

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Kamil Water Pump	KAMILWPP01B	2x6	6
Tawi Aishah	TWIAISHAP01B	2x6 + 1x6	12
Wafi Temp	WAFIP11B	2x6	6

3.7. AL Wusta Governorate and Surrounding Areas.

The Al Wusta Governorate and its Surrounding areas are supplied with power from various sources, including PDO, Diesel Power Plants, and Marafiq. These power sources serve the entire Al Wusta Governorate as well as the rural areas in Al Dhahirah and South Sharqiyah Governorates. However, those systems are scattered through areas isolated from each other with long-distance separation, with limited or no interconnection between them. The total number of customer services in these areas amounts to approximately 18,665. Table 14 shows all existing primary substations with their installed and firm capacity within Al Wusta Governorate.

Table 14 : AL Wusta Governorate and Surrounding Areas – Power Plant, Grid, PDO and Primary Substations Connectivity

PSS	Installed Capacity (MVA)	Firm Capacity (MVA)
Duqum Grid-Duqm North Switching Station (DNSS1)		
Duqum Old Powerhouse	1x 6	0
Duqum Town 1	2X20	20
Duqum Town 2	2X20	20
Duqum Beach	2X20	20
Duqum South	3X10	20
Duqum Port 1	2X20	20
Duqum Frontier Town	2X20	20
Duqum Port 2(CQPS)	2X20	20
Duqum Grid-Duqm North Switching Station (DNSS1)-Duqm South PSS		
Duqum Airport	2X10	10
Duqum Grid-Duqm North Switching Station (DNSS1)-Duqm Port 1 PSS		
Duqum Dry Dock	1X40+1x15	15
Duqum Grid-Duqm Switching Station (DSS2)		
Duqum PSS	1x6	0
Duqum Fishery (Ind 5)	2x6	6
Duqum IND1 (DILIC)	2x20	20
Duqum IND 2 (KARWA PS)	3X20	40
Duqum IND 3	2x20	20
Duqum Grid-Duqm Switching Station (DSS2)- Duqm IND 2 PSS		
Duqum IND 4	3X20	40
Duqum Grid-Duqm Switching Station (DSS2)- Duqm IND 4-Duqm Gantry SS		

PSS	Installed Capacity (MVA)	Firm Capacity (MVA)
GALONI/AJAIZ	2x3	3
Dahar PSS	2X3	3
Duqm Grid-Duqm Switching Station (DSS2)- Duqum IND 4-Duqum Gantry SS-Dahar PSS		
Rasmadraka PSS	2x3	3
Masirah Power Plant		
Dawwah primary Station	3X6	12
Al Nahdah Primary Substation	2 X 10	10
Ras Hilf Primary Substation	2 X 10	10
MOD Primary Substation	2 X 20	20
Mahout Grid		
New Jouba	2x6	6
Hijj	2x6	6
New Hijj PSS	2x6	6
Mahout Ind	1x6	0
Mudairah	2x6	6
Najdah	2x3	3
Khaloof	2x3	3
Dhafrat	2x3	3
NUHAIDAH PDO		
Nuhaidah	2x3	3
A waifiah	2x3	3
Al Orf	2x1	1
NATIH PDO		
HAMRA AL DRO	2x10	10
ZUBRA	1x1	0
YIBAL PDO		
AL ROB'A AL KHAL	2x10	10
GNS RACK PDO		
GHABET AL HAQF	1x3	0
BURHAN PDO		
BURHAN	1x1	0
KAUTHER PDO		
AL ZAHIAH	1x1	0
Ghaba North		
BUTHAILA	1x1	0
Hima Grid (Suwaihat PDO 132/33)		

PSS	Installed Capacity (MVA)	Firm Capacity (MVA)
New Sahma bus 1	2x20	20
Sahma SS buss F 1	2x6	6
Haima Bus 1	3x10	20
Haima ROB Bus 1	2x20	20
MOD bus 1	1x6	0
Ghafeen PDO (Sayyala switch rack) Tapping Point		
Ghafeen	1x3	0
Saih Nihayda PDO-Qara Alam		
Al Zamaim	1x3	0
BAHJA PDO		
MOD	1x6	0
Ghobrah North PDO		
Ghobrah North	1x3	0
Runib P-SS-PDO		
Goubrah South	1x2	0
Al-khadrah Power Plant		
Lakhbi load	2x6	6
AL Khadra 11KV load	5x12	8

3.8. Al Buraymi Governorate

Al Buraymi Governorate includes Wilayat Al Buraymi, Mahadah and Sunaynah. The number of customers served in Al Buraymi Governorate region is 42,417 which is approximately 3% of the total customer population within NEDC. There are 5 Grid Station (132/33 kV), and 28 primary substations (33/11 kV) are feeding the governorate. Table 15 provides a list of existing primary substations in AL Buraymi Governorate.

Table 15 : Al Buraymi Governorate - Grid and Primary Substations Connectivity

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
Buraimi_A GSS			
AL KHADRA B6 01	KDRB01	2x20	20
AL BURAIMI 01	BRMI01	2x20	20
HAMASSA 01	HMSA01	2x20	20
SA'ARA AL JADIDA 02	SARJ02	2x20	20
Buraymi_B Tx1 & Tx2 GSS			
AL KHDRAH AL JADIDA 01	KDRJ01	2x20	20
AL KHDRAH AL JADIDA 02	KDRJ02	2x20	20
MAHDAH 04	MHDA04	2x20	20

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
MAHDAH 03	MHDA03	1x6	0
AL BURAIMI IND. EST 01	BRIE01	2x6	6
AL BURAIMI IND. EST 02	BRIE02	2x20	20
Buraymi_B Tx3 & Tx4 GSS			
ARDH JAW 01	ARJW01	2x20	20
HAY AL-NAFAHAT 01	HNFT01	2x20	20
SA'ARA AL JADIDA 01	SARJ01	2x20	20
AL ZAROUB 02	ZRUB02	2x6	6
MAHDAH GSS			
AL AFRADH 01	AFRD01	2x6	6
AL RABI 01	RABI01	2x6	6
AL JUWAIF 01	JWIF01	1x3	0
AL KHADRA 01	KDRA01	1x3	0
AL MADAM 01	MDAM01	2x10	10
AL ARHAMIYH 01	ARHM01	2x6	6
AL ZAROUB 01	ZRUB01	2x6	6
AL JEL ^[1]	AJEL01	2x10	10
AL GINENA 01	GNNA01	1x1	0
WADI SAA GSS			
RADAT SA'A 01	RDSA01	2x6	6
HAFEET 01	HFIT01	2x10	10
SELLAHEYAH 01	SLHY01	1x6	0
Saih AL Nafahat	SFNT01	1x6	0
SELLAHEYAH 02	SLHY02	2x20	20

3.9. Al Dhahirah Governorate

Al Dhahirah Governorate includes Wilayat Ibri, Dank and Yanqul. The number of customers served in Al Dhahirah Governorate region is 69,631 which is approximately 5% of the total customer population within NEDC. There are 6 Grid Stations (132/33 & 220/33 kV) and 41 primary substations (33/11 kV) are feeding the governorate. Table 16 shows all existing primary substations with their installed and firm capacity within Al Dhahirah Governorate.

Table 16: AL Dhahirah Governorate - Grid and Primary Substations Connectivity

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
DANK GSS			
AL-MASSRAT 02	MSRT02	1x3	0
ABU KRABAH 01	AKRB01	2x20	20

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
AL-BUSAILI 01	BSLI01	2x6	6
DOWT 01	DOWT01	2x10	10
AL-MAZEM 01	MZEM01	1x6	0
AL RAYHANI 01	RYHN01	2x6	6
HAY AL BARAKAH 01	HBRK01	2x20	20
AL-MAZEM 02	AL MAZEM02	2x6	6
AL SUBAIKI	SBKH01	2x6	6
ALHAIL GSS			
ALAYAT FIDAH 01	AFDA01	2x6	6
AL-MAHUL 01	MHUL01	3x6	12
SAFALAT FIDAH 01	SFDA01	2x6	6
DREEZ GSS			
ABLIH 01	ABLIH01	2x20	20
BAAT 01	BAAT01	2x6	6
AL-DREEZ 01	DREZ01	2x20	20
AL-BANAH 01	BANH01	2x20	20
MAQNYAT 01	MQNT01	2x20	20
AL-NUJAYD 01	NJYD01	2x6	6
AL-ARED 01	ARID01	2x20	20
QARN AL-KABSH 01	QRKB01	2x3	3
AL TAYYEB INDUSTRIAL 01	TYBI01	2x20	20
HUGERMAT 01	HGMT01	2x10	10
KAHANAT 01	KHNT01	2x6	6
IBRI Old Tx3 & Tx4 GSS			
AL-ARAQI 01	ARQI01	2x20	20
AL-MURTAFA 01	MRTF01	2x20	20
AL-EYNIN 01	ANIN01	2x20	20
IBRI Tx1 & Tx2 GSS			
AL-AKHDAR 01	AKDR01	2x10	10
AL-SANAEEYAH 01	SNEY01	3x20	40
KUBARAH 01	KBRH01	2x20	20
MINISTRY OF DEFENSE 01	MODF01	1x3	0
SWAIDA ALMA 01	SWMA01	2x6	6
MAZER'A BIN KHATER 01	MKTR01	2x20	20
AL-SULAIF 01	SLIF01	2x20	20
HAI AL SAADAH 01	HSAD01	2x20	20
AL-MASSRAT 01	MSRT01	1x10	0
Al-Massarar 3	MSRT03	1x6	0
YANQUL GSS			
AL-SAWADER 01	SWDR01	2x20	20
AL RAKEI 01	RAKE01	2x20	20

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
AL-WAQBAH 01	WQBA01	2x6	6
AL-SHWAYAH 01	SHWY01	2x6	6
AL-MUREE 01	MURY01	1x3	0
TAWI AL NAWAMEYA 01	TNWM01	1x3	0

3.10. North Al Batinah Governorate

North AL Batinah Governorate includes Wilayat Shinas, Liwa, Sohar, Saham and Al Khabourah. The number of customers served in North AL Batinah Governorate region is 179,962 which is approximately 14% of the total customer population within NEDC. There are 14 Grid Station (132/33 & 220/33 kV) and 83 primary substations (33/11 kV) are feeding the governorate. Table 17 shows all existing primary substations with their installed and firm capacity within North AL Batinah Governorate.

3.10.1. Wilayat Shinas

Shinas has average of 3% load growth for the next three years and there one major project.

3.10.2. Wilayat Sohar

Sohar has seen growing with demand for the last 5 years within North AL Batinah Governorate where Sohar downtown area is one of the largest commercial and residential areas. In addition, Sohar Free Zone, Sohar Industrial Port and Sohar Industrial Estate area are earmarked for some significant development projects.

3.10.3. Wilayat Saham

Overall load growth in Saham remains constant with an average growth of 4%. There is one major project in Saham.

3.10.4. Wilayat Al Khabourah

Overall load growth in Al Khabourah remains constant with average growth of 3%. there is one a major project.

Table 17: North AL Batinah Governorate - Grid and Primary Substations Connectivity

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
SHINAS_B GSS			
FIZAH 01	FIZH01	2x20	20
SUR AL BALOOSH 01	SURB01	2x20	20
AL RUMAILAH 01	RMLH01	2x20	20
NABER 01	NABR01	2x20	20
NABER 02	NABR02	2x20	20

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
GHADAFAN 02	GDFN02	3x6	12
TEMPORARY-GHADAFAN-03	TEMP03	1x6	0
SUR AL ABRI 01	SABR01	2x20	20
MD SHINAS GSS			
TARIF AL MAKAMRAH 01	TRMK01	2x20	20
AJEEB 01	AJEB01	2x6	6
AL WAJAJAH 01	WJAJ01	2x3	3
KHADRAWEEEN 01	KDWN01	3x20	40
AL UQR 01	AUQR01	2x20	20
AL GHURIFAH 01	GURF01	3x20	40
LIWA Tx1 & Tx2 GSS			
AL JUFFRAH 01	JFRH01	2x20	20
FALAJ AL QABAIL 03	FAQB03	2x20	20
GHADAFAN 01	GDFN01	2x20	20
LIWA AL JADIDAH 01	LIWJ01	2x20	20
AL KHUWAYRIYAH 01	KWRH01	3x20	40
LIWA Tx3 & Tx4 GSS			
Airport	SAPT01	2x10	10
SOHAR INDUSTRIAL ESTATE 01	SIET01	3x20	40
SOHAR INDUSTRIAL ESTATE 02	SIET02	3x20	40
SOHAR INDUSTRIAL ESTATE 03	SIET03	2x20	20
SOHAR INDUSTRIAL ESTATE 04	SIET04	2x20	20
SOHAR INDUSTRIAL ESTATE 05	SIET05	2x20	20
SOHAR SFZ Tx1 & Tx2 GSS			
LIWA 01	LIWA01	2x20	20
SOHAR FREE ZONE 01	SFZN01	2x20	20
SOHAR SFZ Tx3 & Tx4 GSS			
FALAJ AL QABAIL 02	FAQB02	2x20	20
WADI AL OWAINAH 01	WOWN01	2x10	10
FALAJ AL SUQ 01	FASQ01	2x6	6
SOHAR Industrial Port GSS			
AL GHUZIL 01	GUZL01	2x6	6
FALAJ AL QABAIL 01	FAQB01	2x20	20
SOHAR INDUSTRIAL PORT 01	SIPT01	2x20	20
SOHAR INDUSTRIAL PORT 02	SIPT02	2x20	20
SOHAR INDUSTRIAL PORT 03	SIPT03	2x20	20
SOHAR INDUSTRIAL PORT 04	SIPT04	2x20	20
SOHAR Tx1 & Tx2 GSS			
AL HOJRAH 01	HJRH01	3x20	40
AL WOQAIBAH 01	WQIB01	2x20	20
AL HUMBAR 01	HMBR01	3x20	40
SOHAR HOSPITAL 01	SHOS01	2x10	10

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
SOHAR Tx3 & Tx4 GSS			
AL MULTAQA 01	MLTQ01	3x20	40
AL TAREEF 01	TREF01	3x20	40
AL MUWAILH 03	MWLH03	2x20	20
WADI SALLAN 01	WSLN01	2x20	20
FALAJ AL-OUHI 01	FOHI01	2x20	20
AL GHUSHBAH 01	GSHB01	2x10	10
UWAYNAT Tx1 & Tx2 GSS			
OUTAB 01	OUTB01	2x20	20
MAJAZ AL KUBRA 01	MJKU01	2x20	20
AL KHISHDAH 01	KSDH01	2x20	20
AL UWAINAT 01	UWNT01	2x20	20
UWAYNAT Tx3 & Tx4 GSS			
PALM GARDEN 01	PGRD01	2x20	20
AL MUWAILH 02	MWLH02	2x20	20
AI SUWAIHRAH 01	SWHR01	2x20	20
HIL AL ASHKAREEN 01	HASK01	2x3	3
WADI AHIN 01	WAHN01	2x6	6
HAY AL-REFAAH 01	HRFA01	2x6	0
Wadi Al Halti	WHLT01	2x6	6
SAHAM GSS			
AL HUWAIL 02	HUWL02	2x20	20
AL HUWAIL 01	HUWL01	2x20	20
SAHAM INDUSTRIAL 01	SHMI01	2x20	20
AL FALAIJ 01	FLAJ01	2x20	20
AL MAHAB 01	MHAB01	2x6	6
MUKHEILIF JADIDAH 01	MKLJ01	2x20	20
HILLAT AL SUQ 01	HLTS01	2x20	20
WADI HIBI	WHBI01	2x10	10
DAS GSS			
MUKHEILIF 01	MKLF01	2x20	20
DIL AL ABDASALAM 01	DASL01	2x20	20
UMM AL JARIF 01	JARF01	2x20	20
HAFEET 01	HFET01	2x20	20
HAFEET 02	HFET02	2x20	20
AL HEJARI 01	HJRI01	2x20	20
KHABOURAH GSS			
AL KHABOURAH 01	KHBR01	2x20	20
AL KHABOURAH 02	KHBR02	2x20	20
QASBIYAT AL HAWASINAH 01	QHWS01	2x20	20

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
AL BREIK 01	BREK01	2x20	20
AL LEHBAN 01	LHBN01	2x6	6
SANA BANI GAFFER 01	SBGF01	2x6	6
WADI BANI OMAR 01	WBOM01	2x6	6
AL HAILASHI 01	HLSH01	2x3	3
AL KASF 01	KASF01	2x20	20
AL KASF 02	KASF02	2x6	0
Khadra-A			
Badi Amoud	BADIAMODP01B	2x20	20
Bidayah	BIDAYAHP01B	3x20	40
Diyan	DIYANP01B	2x20	20
Khadra	KHADRAP01B	2x20	20
Suwaig Shabiyah	SWQSHBYHP01B	1x6 + 1x6	6
Suwaig ROP	SWQROPP01B	2x6	6
Khadra-B			
Alam	ALAMP01B	2x6	6
Khadra Bu Reshaid	KBRSHAIDP01B	2x20	20
Nasr Marble Factory-1	NSRMRBLFP01B	2x6	6
Nasr Marble Factory-2	NSRMRBLFP02B	2x6	6
Saih Rahamat	SIHRHMATP01B	1x6	0
Uriq	URIQP01B	3x20	40
Wadi Haimly	WDIHIMLYP01B	2x6	6
Wadi Jahawer	WDIJHAWRP01B	2x6	6
Bidayah Ind Area	BDAYHINDP01B	1x6	0
Bidayah Souq	BDAYHSUQP01B	2x6	6
Suwaig			
Bathaa	BATHAAP01B	3x20	40
Subaykhi	SUBAYKHIP01B	3x20	40
Suwaig	SUWAIQP01B	2x20	20
Suwaig Ind Area	SWQINDP01B	2x6	6

3.11. Musandam Governorate

Musandam Governorate includes Wilayat Khasab, Madha, Dibba and Bakha. The number of customers served in Musandam Governorate region is 17,192 which is approximately 1 % of the total customer population within NEDC. Musandam Governorate's overall demand growing slowly until recently when development in the major cities of Khasab, Bakha and Dibba have seen steadily increasing growth in

the form of new residential and commercial loads. Table 18 shows all existing primary substations with their installed and firm capacity within Musandam Governorate.

Table 18: Musandam Governorate - Grid and Primary Substations Connectivity

PSS	PSS Code	Installed Capacity (MVA)	Firm Capacity (MVA)
KHASAB GSS			
KHASAB 01	KHSB01	4x20	60
LIMA 01	LIMA01	2x6 + 1X3	6
MAHAS 01	MHAS01	2x20	20
SIBI 01	SIBI01	2x3	3
SAWI 01	SAWI01	2x6	6
WADI BANA 01	WBNA01	2x1	1
QUADA 01	QUADA01	1x2 + 1x3	2
AL HARF 02	HARF02	1x1	0
AL HARF 01	HARF01	2x20	20
AL HABALIN 01	HBLN01	1x1	0
KUMZAR 01	KMZR01	2x6	6
TIBAT GSS			
KHASAB INDUSTRIAL AREA 01	KSBI01	1x6	0
WADI MAWA 01	WMWA01	1x1 + 1x3	1
GHUMDHA 01	GMDH01	2x10	10
AL JERY 01	JERY01	2x10	10
MOD - BUKHA 01	MODB01	2x6	6
DIBBA GSS	It is 132/11 kV Grid Station. So, no PSS is connected in this Grid.		
MADHA (Isolated)	MDHA01	11.3 MW (D.G)	11.3

4. NEDC DISTRIBUTION SYSTEM

4.1. Introduction

NEDC is authorized to undertake all regulated activities of electricity distribution business at 33kV and below across the whole area of Sultanate of Oman excluding Dhofar Governate.

The distribution system has three nominal voltages, i.e., 33kV, 11kV and 415V. Most customers connect at LV (415 Volt) and there are bulk customers connected at 11kV and 33kV.

During 2024, the total Firm capacity for all governorates is circa 11,400.5 MVA, where the maximum load (non-coincident) is around 8,116 MVA which is 71% utilization of the firm Capacity. The below table and figure present these data.

Table 19: Summary of Firm Capacity and Max Load per Governorate

Governorate Name (2024)	Max Load (MVA)	Firm Capacity (MVA)	Utilization %
Muscat	3,082	4,279.5	72%
Buraymi	221	312	71%
Al Dhahirah	389	497	78%
North Batinah	1,441	1,915	75%
Musandam	92	151	61%
Dakhiliah	862	1,345	64%
South Batinah	917	1,120	82%
North Sharqiyah	444	566	78%
South Sharqiyah	497	660	75%
Wusta	170	555	31%
Total	8,116	11,400.5	71%




Figure 2: Utilization % from Firm Capacity per Governorate

System maximum demand is occurring generally during summer period; although there seems to be no exact correlation on the exact timing as expected. There are various parameters which affect the occurrence of the system maximum demand hence the future forecast; we expect more parameters in the upcoming future especially due to the macro-economic condition of the Oman economy and due to the developments in newer technologies. Few of the significant parameters which have impacted NEDC distribution system growth in 2024 and future are:

- Temperature and Humidity.
- Customer numbers and types of customer's growth.
- Socio-economic factors like state of economy due to oil prices.
- Implementation of CRT and the continuous effect.
- Introduction of Tariff reforms for all.

This can result in a lack of consistent predictability as to the precise date of future system peaks, although provides a good indication in general of the period and pattern. For this reason, associated demand transfers are operationally planned to occur before May period each year to ensure NEDC are in the best position possible to meet regulatory requirements and ensure quality and security of supply to consumers.

4.2. System Demand and Load Duration

Figure 3 below shows the historical data [2018-2024]; the system MIS maximum demand and % growth excluding Al Wusta and Musandam. In addition, Al Wusta and Musandam Governorate historical data are illustrated in Figure 4 and Figure 5.




Figure 3: System Max Demand (MW) MIS




Figure 4: System Max Demand (MW) Al Wusta




Figure 5: System Max Demand (MW) Musandam

The Maximum and Minimum Demand for the NEDC distribution systems in 2024 is illustrated in Figure 6 and Figure 7 below. This shows that the 2024 minimum demand is circa 36% of the 2024 maximum demand for the MIS NEDC system.




Figure 6 : Hourly Demand – MIS System Maximum and Minimum Day Profile




Figure 7 : Hourly Demand – Musandam System Maximum and Minimum Day Profile

The Maximum load profiles for NEDC taken on Thursday, 26th June 2024, the day of NEDC Peak, were plotted and presented in Figure 6. The highest load was reached at 14:43 hours; on this day, the load recorded was 7,326.6¹⁰.

4.3. Cost Reflective Tariff (CRT)

In October 2016, The Regulator announced that the Council of Ministers had approved the introduction of a new tariff for high value customers called the Cost Reflective Tariff (CRT) and implemented fully in 2017. The new tariff is designed to reflect the actual costs of providing a supply of electricity more accurately to large government, commercial and industrial customers without government subsidy. Till 2020 the approval for CRT implementation is for application only to the high value customers who consume 150 MWh and above in a year, for the above-mentioned customer categories.

¹⁰ MIS Transmission peak excluding of transmission technical losses and Grid Stations auxiliary load

In 2021, CRT was revised, and the current approval is for application to the high value customers who consume 100 MWh and above in a year and the new tariff is designed to all the customer category except residential customers.

As the full 2024 cycle hasn't been completed yet, an impact analysis was undertaken on 2023 NEDC customers base to understand the full year impact of CRT on the NEDC distribution system and described as below.

The number of CRT customers in 2024 was 19,317, circa 1.5% of the total connected customers. **Error! Reference source not found.** below shows some of high consumption customers load profiles during peak day and the direct effect of CRT tariff during 2024 peak hours.




Figure 8: CRT Customer During System Peak 26 Jun 2024

4.4. Demand Not Secured (DNS)

As per the licence condition, NEDC is obliged to comply with the DSSS and moreover one of our major investment drivers for the CAPEX programme is to meet the N-1 operational capability for each Primary Substation.

Figure 9 below provides a trend of the NEDC Demand Not Secured (DNS) MVA performance as a measure to show DSSS compliance improvement along with number of Primary Substations contributing to the DNS. The audited 2023 DNS is 431.7 MVA which is a circa 26.9 % higher compared to 2022 DNS value of 340.3 MVA and this due to delay in some project which was expected to be energize before summer 2023.

NEDC distribution system is mixed of urban dense interconnected network and rural areas. Therefore, for urban areas the network design optimum effort is made to maintain that level of interconnection leading to majority of the 11kV feeders except minor rural feeders having no single but multiple interconnections. Hence majority of the 11kV feeders will come under the Class A and Class B

categories. Typically, with the assistance of these 11kV interconnections, the supply can be generally restored within the allowed DSSS time frame. However, for the rural area feeders the automation and fast isolation of faulty section will play an important role in optimizing the operation of the 11kV network.




Figure 9 : History of NEDC Demand Not Secured and Out of Firm PSS

4.5. 11kV Feeder Loadings

As detailed in the Appendix B-5, 45 number 11kV feeders were observed in 2024 which exceeded the derated thermal loading limit under normal operational configuration; these will be solved by appropriate 11kV load transfers, projects schemes in 2025 and 2026 itself shown in Table 20 below. The maximum loadings of all the 11kV feeders are attached in Appendix B-5.

Table 20: 11kV Highly Loaded feeder Plan

PSS Name	Plant Code	Feeder Code	Feeder Rated Capacity [Amp]	Feeder De-rated Capacity [Amp]	Actual Load Amps 2024 [Amp]	Plan
Muscat Governorate						
Quriyat[G05]						
Quriyat	P091	KLN06	400	350	356	50% of the load will be transferred to Al Shahbari KLN04
Amerat[G10] - A						
Amerat Heights	P152	KLN04	400	350	384	New feeder from Amerat Amerat 4 PSS will share the load before summer 2025
Amerat Heights	P152	KLN07	400	350	371	New fresh feeder from the same PSS
Amerat 3	P179	KLN11	400	350	367	New fresh feeder from the same PSS
MSQ[GP06] – B						
MSQ 1	P083	KLN05	400	350	373	New feeder from same PSS will share the load and the effect will be before summer 2026
Bousher[GP02] - B						
Bousher 2	P163	KLN08	400	350	368	New feeder from same PSS will share the load and the effect will be before summer 2026
Bousher 2	P163	KLN11	400	350	379	New feeder from same PSS will share the load and the effect will be before summer 2026

PSS Name	Plant Code	Feeder Code	Feeder Rated Capacity [Amp]	Feeder De-rated Capacity [Amp]	Actual Load Amps 2024 [Amp]	Plan
Al Muna	P084	KLN06	400	350	371	New feeder from same PSS will share the load and the effect will be before summer 2026
Ghala Heights[G24] A						
Al Ansab 1	P007	KLN06	400	350	370	New feeder from same PSS will share the load and the effect will be before summer 2026
Ghala Heights[G24] B						
Azaibah South 1-B	P147	KLN03	400	350	376	New feeder from same PSS will share the load and the effect will be before summer 2026
Ghala[G11] - B						
Ghala 2	P156	KLN02	400	350	378	New feeder from same PSS will share the load and the effect will be before summer 2026
Ghala 2	P156	KLN05	400	350	358	New feeder from same PSS will share the load and the effect will be before summer 2026
Al Ansab 2	P008	KLN09	400	350	356	Internal load shifting
Misfah[G04]						
Al Misfah	P080	KLN09	400	350	368	New fresh feeder from the same PSS in 2026
Al Awabi	P139	KLN11	400	350	350	New fresh feeder from the same PSS in 2026
Mabelah[GP04]						
Mabelah Grid	GP04	KLN05	400	350	363	New fresh feeder from the same PSS in 2026
Sur Al Hadid	P116	KLN01	400	350	379	New Feeder from Sur Al-Haid P116 in 2025
Botanic Garden	P016	KLN02	400	350	385	New fresh feeder from ROP P161 to connect with existing Cable from DSS 132 RMU in 2025
Mabella 2[G12] - A						
Mabelah C	P064	KLN12	400	350	396	New fresh feeder from the same PSS in 2026
Mabelah South PH-4	P062	KLN04	400	350	376	New feeder from Seeb Mabelah South P185 in 2026
PalmMall	P168	KLN11	400	350	356	New feeder from Seeb Mabelah South P198 in 2026
Mabella 2[G12] - B						
Mabelah Shabiya	P060	KLN15	400	350	374	Internal load shifting
Seeb Mabelah South [PH-6]	P185	KLN06	400	350	359	New Feeder from Seeb Mabelah South P198
Mabelah Industrial[G26] A						
Mabelah South PH-8	P157	KLN01	400	350	362	Internal load shifting
Mabelah South PH-8	P157	KLN13	400	350	370	Internal load shifting
Mabelah South PH-7	P141	KLN02	400	350	352	New fresh 11 kV feeder to take some load of both feeders KLN02 and KLN05 in 2026
Mabelah South PH-7	P141	KLN05	400	350	362	New fresh 11 kV feeder to take some load of both feeders KLN02 and KLN05 in 2026
Mabelah South PH-7	P141	KLN13	400	350	354	New fresh feeder from the same PSS in 2026
Seeb[GP08] - A						
Al Khoud Shabiya	P046	KLN07	400	350	374	New fresh feeder from the same PSS in 2026
Mawaleh South[GP05] A						
Al Hail North 2	P028	KLN09	400	350	363	Internal load shifting

PSS Name	Plant Code	Feeder Code	Feeder Rated Capacity [Amp]	Feeder De-rated Capacity [Amp]	Actual Load Amps 2024 [Amp]	Plan
Mawaleh South Grid	GP05	KLN01	400	350	354	New Feeder from Seeb Muskar Murtafiah P197 in 2025
Mawaleh South[GP05] B						
Al Khoud PH-6	P049	KLN02	400	350	366	New fresh 11 kV feeder to take some load of both feeders KLN02 and KLN03 in 2026
Al Khoud PH-6	P049	KLN10	400	350	382	New feeder from ROP AL-Khoudh P161 & Seeb Mabelah South P198 in 2025
Al Khoudh[G25] A						
Mawaleh A	P070	KLN09	400	350	356	New fresh feeder from the same PSS in 2026
Al Khoud PH-3	P048	KLN06	400	350	351	Internal load shifting
Seeb Khoudh [Al Khoud Shabiya (B)]	P187	KLN09	400	350	381	New fresh feeder from the same PSS
Al Khoudh[G25] B						
Al Khoud PH-7	P154	KLN01	400	350	390	New feeder will share the load from same PSS and the effect will be before summer 2026
Al Khoud PH-7	P154	KLN02	400	350	393	New feeder will share the load from same PSS and the effect will be before summer 2026
Al Khoud PH-7	P154	KLN06	400	350	388	New feeder from ROP AL-Khoudh in 2025
South Batinah Governorate						
Madinat Barka-A						
Saqsuq	SAQSU QP01B	33L5	400	350	389	New feeder from same PSS will share the load and the effect will be before summer 2025
Dakhiliah Governorate						
Jabrin Grid						
Bidoou	BIDOO UP01B	23L5	400	350	354	Some load will be transferred to new Bahla PSS before summer 2025
Nizwa Grid						
Manah	MANAH P01B	27L5	400	350	378	New feeder from same PSS will share the load and the effect will be before summer 2026
North Sharqia Governorate						
SAMAD GRID						
Samad	SAMAD P01B	28L5	400	350	358	Internal load shifting
Sinaw Grid						
Sinaw 2	SINAW P02B	25L5	400	350	356	Some load will be transferred to Sinaw 3 PSS before summer 2025
North Batinah Governorate						
LIWA TX.1 & TX.2						
LIWA AL JADIDAH 01	LIWJ01	KLN02	400	350	356	New fresh feeder from same PSS will share the load - 11kV projects 2024

4.6. System Demand Forecast

Accurate and realistic load demand forecasting is critical for the effective operation of the distribution system and is the principal driver for capital expenditure. Realistic assumptions must be made for inherent uncertainties in forecasting and the underlying socio-economic factors, such as the sustained low oil price, population growth and impact of Oman wide customer tariff reforms.

Load growth can vary from year-to-year and is not uniform across the whole system. It is not unusual to find parts of the system growing at significantly higher rates than the system, while other parts of the system can experience periods of low growth or demand reduction.

The forecast model has inputs data from different sources as follows:

- Population data for the area served by NEDC has been taken from data published by the Oman Information and Statistics Centre.
- Data and projections on Oman's GDP economic development are taken from the International Monetary Fund published in its World Economic Outlook Database.
- GIS (Geographic Information System) and CRM (Customer Relationship Management) provide customer account details internally in the company. These two systems offer the customer account numbers with the connected demand and the primary substations connected to these accounts.
- SCADA provides internally the primary substation's peak loads (Supervisory Control and Data Acquisition).

Then the model will have several calculations using the input data to reach the load growth of each primary substation applied in this capability statement.

NEDC considers the following features are necessary to produce an accurate demand forecast in line with best practice:

- Accurate and unbiased actual demand data – careful management of data and forecasting model construction based on sound theoretical grounds that closely fits the sample data.
- Transparency and repeatability – as evidenced by good documentation, including documentation of the use of judgment, which ensures consistency and minimizes subjectivity in forecasts.
- NEDC also considers the following elements to be relevant to maximum demand forecasting:
 - Independent forecasts – spatial (bottom up) forecasts should be validated by independent system level (top down) forecasts and both spatial and system level forecasts should be prepared independently of each other. The impact of macroeconomic and demographic trends is better able to be identified and forecasted in system level data, whereas spatial forecasts are needed to capture underlying characteristics of specific areas within the system. Generally, the spatial forecasts should be constrained (or reconciled) to system level forecasts;

- Adjusting for temporary transfers – spatial data is adjusted for historical spot loads arising from peak load sharing and maintenance, before historical trends are determined;
- Adjusting for discrete block loads – large new developments, such as shopping centres and housing developments, are incorporated into the forecasts, taking account of the probability that each development might not proceed. Only block loads exceeding a certain size threshold are included in the forecasts, to avoid potential double counting, as historical demands incorporate block loads and general demand growth.

At the time of writing this DSCS, the volume of grid connected PV systems is expected to make minor impact at system level forecast (including future years as it stands); hence the impact of PV systems is not included in the forecast for this DSCS. With the development of our new regression-based Load Forecasting tool, NEDC will monitor the uptake of all low carbon technologies including PV and include the impact of these on forecast in future appropriately.

4.6.1. Load Forecasting

To address the various uncertainties impacting the forecasting in recent times and going forward as mentioned above; NEDC has an econometric forecast modelling tool rather than historically used Compound Annual Growth Rate (CAGR%) method. The model uses regression analysis to identify relationships between historic system data and historic economic variables. The primary economic variables considered are population growth and the growth in GDP (broken down by economic activity).

These two drivers are commonly accepted as being key descriptive drivers of future growth in underlying RUD and CA and by combining the historic regression-based relationship data to forecasts of the economic variables, projections of CA growth and RUD growth can be made (with average consumption per customer also identified).

Moreover, the tool can capture the Low Carbon Technology (LCT) impacts on load growth; these will be considered in future forecasts as these impacts on system demand become significant in future. In addition to the above, the impact of individual large investment projects is also considered separately. These projects are projected to bring around a one-off increase in demand, which is not captured by the economic forecast model. By undertaking sensitivity analysis, the model provides a complete envelope of extremes for the forecasted parameters rather than relying on one-point values.

4.6.2. System Demand Growth

Historical data indicates that the demand rate of growth across NEDC distribution system has slowed in recent years. This is mainly attributed to the sustained low price, general macro-economic factors and exceptional events around the world. The average load growth for the forecasted three years, using the Regression model, is 5.9%. Table 21 shows the actual and forecasted NEDC expected peak demand including and excluding the direct connected customer load.

Table 21 : NEDC Non-Coincidence Forecast with Growth

Year	2024	2025	2026	2027
Total NEDC Connected to MIS (MW)	6,878	7,303	7,705	8,070
AL Wusta connected to MIS (MW)	75.0	79.9	154.9	177.1
Al Wusta D.G and PDO (MW)	73	71	42	41
Musandam (MW)	93.3	97.7	102.6	108.3
Madha (MW)	8	8	9	9
Ground Total (Excluding Grid Connected Customers (MW))	7,127	7,560	8,013	8,406
Yearly Growth %	6.8%	6.1%	6.0%	4.9%

Figure 10 shows the historical trend in NEDC system maximum demand with the forecast maximum demand over the period 2025 to 2027. Despite the general slowing in demand growth at the system level, there are areas within the system where maximum demand is forecast to grow well beyond the system average level, while other parts of the system are forecast to experience no load growth or a small reduction in maximum demand.




Figure 10 : Historical Trend in NEDC System Maximum Demand with Three Years Forecast

The peak load of NEDC increases gradually, but the growth changes from year to year depending on the situation of each year. Figure 10 indicates that from the historical and forecast data [2018-2027]; NEDC demand growth expected to continue growing with average rate of 6% for the next three coming years. This expected growth driven by a considerable number of governmental investments in tourism projects, infrastructure projects, industrial projects, and private sector investments accompanying them.

There are two separate networks in Musandam Governorate: Main network which consists of three Grid Stations (Tibat, Khasab and Dibba Grid Stations). This network is supplying around 99% of Musandam Governorate. The second network is Madha network. Madha is a small Wilayat surrounded by the UAE therefore the power system there consists of 6-11kV diesel generators (with total capacity of 11.3 MW) located in Madha Primary Substation. In 2024 summer, recorder peak load of Madah substation was around 7.6 MW and it is forecasted to remain almost the same for the period of 2025 to 2027 as there

is no expectation for new major development in Madha. Overall Musandam load growth expected to grow within the limit of 5.2% as seen in Figure 11 below.




Figure 11 : Musandam 2018-2026 Peak Load with Growth percentage

Currently, most of the distribution networks in the Al Wusta Governorate and rural areas in other governorates are powered by diesel-fuelled power plants, which operate as isolated systems in different areas. There are 12 power plants distributed throughout the whole of Al Wusta and surrounding areas. NEDC has a plan to reconfigure these networks' power sources to be connected to the Main Interconnection System (MIS) and align with the OETC Interconnection Plan in the Phases I & II of "Rabt" project. Table 22 below displays the NEDC plan and the target date for the interconnection with MIS.

Table 22: Al Wusta Diesel Plants

Power Plant	Target Date
Masirah	Q4,2026
Hijj	Completed
Al-Khuwaima	Q4,2026
Dhafrat	Completed
Khalouf	Q2,2026
Najdah	Q2,2026
Sarab	Q2,2027
Duqm	Completed
Masrooq	Q2,2029
Khadra	Q2,2028
Hitam	Q2,2028
Wadi Aswad (Nuhaidah & Hamara AL Droua areas)	Q2,2028

In 2024, The peak load in the Al Wusta Governorate and its surrounding areas has reached 150 MW, including the PDO source connections; Al Wusta system maximum demand continues rising compared to the previous years in 2026 by around 30%. This high growth increase can be referring to the new bulk load that intended to be connected in AL Duqum (29 MW of Cement factory). Similarly in 2027, 15 MW will be connected as new bulky loads for the new EZAD industrial area in Ibri. Overall, Al Wusta load

growth expected to be within 14.3% between 2025 to 2027 including the bulky load connections as seen in Figure 12 below.




Figure 12 : AI Wusta 2018-2026 Peak Load with Growth percentage

4.7. Distribution System Modelling and Analysis

NEDC maintains up-to-date models of its power system for assessing distribution system performance via power system studies, bulk loads modelling, and undertaking customer connection studies where required; to ensure the distribution system operates in a safe and an efficient manner along with providing the required security of supply to its connected customers.

4.7.1. Power System Models

The planning tool utilised for system modelling and studies are PSS®SINCAL (Power System Simulator® Siemens Network Calculation), ETAP (Electrical Transient and Analysis Program) and DigSILENT (Digital Simulation and Electrical Network calculation program). The models for each grid substation with their respective connected primary substations are established by representing the 33kV system on an electrical connectivity basis. The system models contain network topology and details in terms of nameplate data for transformers and their tap changers, capacitor banks and their controllers, conductor types along with associated lengths and parameters and the non-coincident demand data on individual primary substations.

The load demands are modelled as lumped loads connected to the main 11kV bus bars and segregated into motoric and non-motoric load types for load flow and fault current calculations. Likewise, the existing connected solar PV plants are also modelled as lumped generation on 11kV bus bars from this year onwards. The recorded maximum (summer) demands on each primary substation; derived from NEDC SCADA system as of 2024 have been used to update the power system models on non-coincidental load basis. Forecasting principles for load determination as mentioned in the previous sections have been adopted to forecast the future year (2025-2027) maximum demands.

4.7.2. Load Flow Analysis

Load flow analysis is undertaken for maximum demand scenarios to define the performance of NEDC distribution system. The analysis determines the active and reactive power flows in the system, percentage loadings for transformers and 33kV circuits along with the voltage profile at the 11kV and 33kV busbars of the primary substations under normal circuit operation. Simulations are carried out for the existing (2024) and future 3 years (2025-2027) for system maximum loadings. All short circuit results have been listed in a downloadable excel sheet files as following:

- Primary Substations Loading in Appendix B-1.
- 33kV feeders loading in Appendix B-2.
- Non-compliance Bus-Voltages in Appendix B-3.
- Short Circuit Fulat Results in in Appendix B-4
- 11kV feeders Loading in Appendix B-5.

From the studies, it is possible to identify where the system is strong and has spare capacity and conversely, where additional mitigation and/or reinforcement, before new connections, potentially needs be considered. The maximum demand case for instance; identifies where there is a risk of overloading, of operation above firm capacity, or of system voltages falling below the voltage limits.

The power factor values for maximum demand scenarios have been determined based on the actual available information from NEDC SCADA. For maximum demand conditions, the actual recorded power factor data is employed, where available. For the remaining substations, where power factor values are not available via SCADA, a calculated system average is considered for maximum demand scenarios in accordance with the company's defined practice.

The load flow study results are summarised in tabular form in Appendix B-1 and available in a downloadable excel files that supplements this Distribution System Capability Statement.

The simulation results demonstrate the following within the period of this DSCS:

- Voltage drop under maximum demand scenario remains within the statutory limits of - 6% on all 33kV busbars/nodes.
- Voltage drop under maximum demand scenario remains within the statutory limits of - 6% on all 11kV busbars/nodes.
- 33kV circuit loadings assessed for the worst-case maximum demand scenario; across the system are within the acceptable circuit ratings.

From the results it can be observed that 38 primary substations are facing voltage drop in 2024 below the statutory limit of $\pm 6\%$ at the 33kV busbars. However, the 11kV busbars are complying with the statutory voltage limits with consideration of operating the capacitor banks and the transformer tap-changer at the suitable tap position except 3 PSS. By 2027, the number of primary substations facing voltage drop at the 33kV busbar will be reduced to 31 as a results of network expansion where new

33kV lines will be introduced in the system. NEDC will continue monitoring these primary substations to ensure keeping the 11kV network within statutory voltage limit of $\pm 6\%$. Moreover, NEDC will keep in consideration to improve the 33kV voltage through providing new 33kV lines or installing new Grid connection points whenever is possible.

4.7.3. Short Circuit Analysis

NEDC carries out short circuit calculation studies to establish the capability of equipment to withstand three phase maximum prospective fault current levels. All short circuit results have been listed in excel sheet file in Appendix B-4.

The principal source of fault currents is the generation assets connected to the transmission system with the fault current contribution onto the NEDC distribution system via the 132/33kV GSS transformers. The fault current infeed from the OETC source have been updated in our power system models according to the data provided by the OETC's 2024 Capability Statement which covers up the transmission system developments up to 2027.

The system configurations modelled for short circuit studies in each year, to represent the maximum prospective fault current levels, while also reflecting the realistic operational arrangement are based on the following principles:

- All existing and new 2x20 MVA PSSs are simulated for operation with the 11kV bus-section circuit breaker in the “normally closed” position¹¹.
- All existing and new 3x20 MVA PSSs are simulated for operation with one 11kV bus-section circuit breaker as “normally closed” and one as “normally opened” (i.e., in N or N-1 scenario, it represents a 4 out of 5 ‘normally closed’ circuit breakers scenario) with an auto transfer scheme (ATS)¹².
- All existing 2x20 MVA PSSs and 3x20 MVA PSSs are simulated for operation of 33kV bus-section circuit breakers within the PSSs (wherever present)¹³ as “normally open”.
- All existing and new outdoor primary substations (3x6MVA, 2x6 MVA, 2x3 MVA and 2x1 MVA) are simulated for operation with the 11kV bus-section circuit breaker in the “normally open” position.

¹¹ Except for few locations where the 33kV feeders for the individual transformers are connected from two different GSSs in which case, the 11kV bus-section circuit breaker is kept “normally open” for the respective year(s).

¹² If the fault levels are within limits for this worst-case scenario's then on bus-coupler open scenarios of existing primaries the fault level's will be even lower.

¹³ For new PSS, the 33kV configuration excludes the 33kV bus-section circuit breakers at the PSS.

The design short circuit breaking ratings of the 11kV switchgear component a new and upgraded primary substations are designed to 18.4 kA or higher based on short circuit requirement to comply with system requirements.

Currently, in the absence of accurate fault level contribution data from low voltage (LV) side, a worst-case allowance is made for LV motor fault contribution majorly due to the nature of the air conditioning load prevalent across the NEDC's distribution system. A motoric to static load type ratio of 80/20 (in percentage) is considered using the system maximum demand values. System modelling for fault current calculations have been performed in accordance with the principles of the "IEC 60909-Short Circuit Currents in 3 Phase AC Systems" standard.

The maximum prospective fault current values are tabulated in the tables in Appendix B-4. The calculation of maximum prospective fault current is compared against the rated breaking capability of the primary equipment.

The maximum prospective (initial symmetrical) fault current is calculated to be still under but approaching (i.e., >95% and <100%) the rated breaking capacity of the primary 33kV equipment (switchgear) at the following primary substations:

- Wadi Adai-P175 (24.18 kA in 2024, then within 95% and 23.91 kA by 2027)
- Bousher G-GP02 (23.81 kA in 2024, 24.19 kA by 2025 and 24.2kA in 2026 & 2027)
- Seeb Grid-GP08 (23.84 kA in 2026 and 2027)
- Mawaleh South Grid-F1-GP05 (25.7 kA in 2024, 26.1 kA by 2025, 26.5kA in 2026 and 26.9 kA 2027)
- Mawaleh North Grid-GP01(24.461 kA from 2026 to 2027)
- Barka-5 IWP (24.24kA from 2025 to 2027)
- Barka Pumping Station PSS (26.09 kA by 2027)
- Sur IWP 2 (23.43 kA in 2024)
- Rusail Industrial 1-P103 (24.066 kA in 2024)
- Rusail Private Factory-P106 (24 kA from 2024 to 2027)
- Mabelah Grid-GP04 (23.96kA in 2027)
- MSH02-P00X (24.952kA in 2027)
- Sur IWP (23.98 kA from 2024 to 2027)
- Hay Sharq Temp (24.36 kA by 2024)

However, at the following primary substation(s), minor excursions beyond the rated breaking capacity of the 33kV equipment (switchgear) are observed:

- MSQ Grid-GP06 (25.2 kA by 2024 (101% of 25 kA rating))
- Rusail Ind 4-P158 (25.934 kA by 2024 (104% of 25 kA rating))
- Rustaq Grid (41.946 kA by 2024 (168% of 25 kA rating))
- Nizwa Grid (29.9 kA in 2024 and 27.49 kA by 2027 (113% of 25 kA rating))

- Izki Grid (28.104 kA in 2024 and 24.8 kA by 2026 (99.9% of 25 kA rating))
- Sur Grid (26.22 kA from 2024 and 26.51 by 2027 (106% of 25 kA rating))
- Mudhairib Grid (26.6384 kA in 2025 and 28.13163kA by 2027 (113% of 25 kA rating))
- Nizwa ROP (24.83 kA in and 24.66 by 2027)

Where it marginally exceeds above the switchgear rating; hence NEDC shall monitor this PSS closely and create mitigation plans in form of operational restrictions if required based on the monitoring results.

It is to be noted that all the above primary substations are in close electrical vicinity of the grids substations where these results are based on non-coincident maximum demand fault contributions to represent worst case scenarios of the connected PSSs.

The maximum prospective (initial symmetrical) fault current levels at 11kV busbars of all the primary substations are within their rated breaking capacities except for the following primary substations:

- Billah (18.63 kA in 2024 (101% of 18.4 kA rating))
- Royal Hospital-P024(20.8 kA in 2024,21.1kA from 2025 to 2027 (104%> of 20 kA rating))

4.7.4. Technical Losses Assessment

The technical losses in the NEDC distribution system are a factor of the configuration of the system, type and specification of equipment, percentage utilisation of assets and customer energy consumption. Technical losses are attributed to load and no-load losses in the 33kV feeders and 33/11.5kV primary transformers, 11kV feeders and distribution transformers and the LV distribution system. In line with standard international practice for utilities where the distribution system is not fully modelled, we calculate the losses for specific network elements (transformers, overhead lines and cables) across the different voltage levels (33kV, 11kV and LV) and then summate the total losses to obtain a percentage technical loss for each primary substation.

The percentage technical losses are then apportioned according to the proportion of total system energy supplied by each substation. A summation of all apportioned technical losses is then presented as the system percentage technical losses. The summated technical losses based on the 2024 distribution system operation is calculated to be 4.86%. The breakdown of technical losses by voltage level is shown in Table 23 below.

Table 23 : Technical Losses

System Component	Zone 1	Zone 2	Zone 3, Musandam & Al Wasta	% Total
33 KV OHL, UGC & PT Losses	0.68%	1.63%	1.35%	1.17%
11 KV OHL & UGC Losses	0.42%	1.05%	1.22%	0.84%
11/ 0.415kV Distribution Tx Losses	1.57%	2.22%	1.63%	1.80%
LT OHL & UGC Losses	1.38%	0.93%	0.69%	1.05%
Total	4.06%	5.84%	4.89%	4.86%

5. CHALLENGES AND OPPORTUNITIES WITHIN THE SYSTEM

5.1. Meeting Oman's Net-Zero 2050

Meeting Oman's Net-Zero 2050 by implementation of Low carbon technologies (LCTs) like Solar PV, Electrical Vehicles (EV), energy efficiency and battery storage are few of the major LCTs successfully being implemented around the globe to achieve sustainability of natural resources and protect the environment. This philosophy is also the cornerstone for Oman as demonstrated in the Oman Vision 2040 Environment and Natural Resources and Oman's Net-Zero 2050 Objective¹⁴. To achieve the above and other sustainable goals of the Sultanate National Energy Strategy for 2040 recommended that around 30% of Oman's generation mix should come from renewable energy sources (RES)—primarily onshore wind and solar—by 2030¹⁵. Lastly the CRT and customer tariff reforms introduced by Oman 2017 onwards are accelerating the adoption of these LCTs.

NEDC recognises that the nature of electricity generation and use is changing. We envisage that recent policy initiatives will result in an increase in photovoltaic (PV) generation on our distribution system. Unlike other utilities in different regions, Oman has not seen significant uptake in electric vehicle charging thus, the associated demand characteristics for electric vehicles (EV) are not considered to be a contributing factor to our system planning in the short-term planning horizon. However, this will be closely monitored to check the penetration rate of EV and PV in general.

5.1.1. Photovoltaic (PV) connections

In accordance with the above, the LCT with significant impact to the NEDC system as of 2024 is Solar PV. In 2017, Authority for Public Services Regulation (APSR) revised the existing regulatory framework to facilitate the adoption of small-scale grid connected solar PV systems by customers in Oman. The PV guidelines detail the following:

- Establishing the minimum technical standards required for small scale grid connected PV systems.
- Detailing the connection process including the installation, metering and operation/maintenance.
- Allowing the distribution companies to act as agents for OPWP (the current single buyer of electricity) to buy PV-generated electricity from customers.

With the introduction of Sahim-I initiative by the APSR since May 2017, there has been an increasing uptake of small grid connected PV systems for households and business as evident from the PV connections list in Appendix B. NEDC does foresee challenges and opportunities in the way we will plan

¹⁴ https://isfu.gov.om/2040/Vision_Documents_En.pdf

¹⁵ <https://www.apsr.om/en/renewableenergy>

and operate our system. Whilst PV may have the impact of reducing transmission and distribution congestion; we do envisage that challenges in terms of power quality, reverse power flow and operating within voltage limits will need to be addressed if PV uptake is significant.

NEDC is responsible for ensuring power quality according to the regulations under which we operate. However, with the addition of intermittent, consumer-owned and non-dispatchable PV units, current standard procedures for guaranteeing power quality might not be as effective as they are without PV.

Overvoltage is one of the main reasons for limiting the capacity (active power) of non-dispatchable PV; that can be connected to a low voltage Distribution System. During high PV generation and low load periods; there is a possibility of reverse power flow and consequently voltage rise in the HV & LV feeder. We envisage that this will be most prominent during the winter period. For this reason, NEDC believe that if uptake is significant, it will impact investment decision making for reinforcement and asset replacement. Consideration of tap range, optimum dispatch of capacitor banks and conductor sizing may be necessary should PV penetration become high.

NEDC continues to experience a surge in applications for connecting solar PV systems of various sizes. As of September 30, 2024, a total of 614 PV systems are connected to the NEDC grid, contributing a combined generation capacity of 59.56 MW. Of these, 166 systems were newly energized in 2024, adding 12.86 MW to the year-to-date total. Additionally, the total number of received applications as of September 2024 has reached 831, representing a total requested generation capacity of 91.37 MW.

Table 24 and Figure 13 and Figure 14 below shows these customer classifications for the applications in the category.

Table 24: 2024 PV connection Applications with total installed PV capacity

Sr.	Category	No. of Connected Applications		Connected Generation [MW]		Total Applications	
		YTD 2024	As End Sep, 2024	YTD 2024	As End Sep 2024	No of applications As End Sep, 2024	Requested Generation As End Sep, 2024
1	Commercial	25	119	8.97	37.94	169	57.94
2	Government	21	82	2.37	15.08	109	22.13
3	Residential	66	336	0.84	4.14	471	5.85
4	Agricultural	54	77	0.67	2.40	82	5.45
Total		166	614	12.86	59.56	831	91.37




Figure 13: Number of PV Applications




Figure 14: Connected Generation from PV [MW]

In accordance with the current Oman regulations the solar PV systems are required to be firstly installed for self-consumption basis before any excess generation is exported to the distribution system for the consumption of other customers. Net metering allows Residential, Government and Commercial customers who generate their own electricity from solar power, to sell the surplus electricity back into the grid.

6. THE INVESTMENT PLAN

6.1. Future System Development Plans

NEDC has prepared a plan for the new investments required in 2025-2027 to reinforce the 33 kV network and ensure compliance with the security standards. Many substations and feeders will start moving toward compliance situation. However, the NEDC investment plan updates annually to cover other substations and feeders that need more investments. NEDC has taken various steps to tackle any bottlenecks in the project management cycle, and with these interventions, our capabilities to deliver all the required capital expenditures will undoubtedly improve.

Table 25 show the summary of planned 33 kV projects in the NEDC network per governorate in the different stages, the details are illustrated in Appendix C.

Table 25: A summary of the 33 kV Expansion Plan

Governorate	NEDC Investment Planning Stage	NEDC Investment Designing Stage	NEDC Investment Tendering Stage	NEDC Investment Execution stage	NEDC Investment Completed
Muscat	1	5	3	7	6
Dakhilah	0	0	0	7	0
South Sharqiyah	0	6	1	4	0
North Sharqiyah	0	0	0	1	0
South Batinah	0	0	0	6	0
North Batinah	3	2	0	2	0
DHAHIRAH	3	1	0	5	0
Buraimi	0	0	0	0	0
Musandam	0	2	0	1	0
Wusta	1	1	0	3	0
NEDC	8	17	4	36	6

Moreover, Table 26 show the summary of sponsored projects in the NEDC network per governorate in the different stages, the details are illustrated in Appendix D.

Table 26: A summary of the Sponsored Projects

Governorate	Sponsored Investment Planning Stage	Sponsored Investment Designing Stage	Sponsored Investment Tendering Stage	Sponsored Investment Execution stage	Sponsored Investment Completed
Muscat	0	0	0	1	0
Dakhilah	0	0	0	1	4
North Sharqiyah	0	0	0	0	1
South Batinah	0	0	0	0	2
Total	0	0	0	2	7

6.2. Network Suitability for New Connections

Since January 2024 up to end of September NEDC connected 34,472 applications with worth of 1,871 MW for both simple and complex connections. The table below shows the statistic for all governorates for both connections. From the table below it was noted that the for the simple connection the average connected load per customer is 0.03 MW. For the complex connection, there two major customers who Sultan Hiatham City and Aida Yitti project with 269.69 MW and 206.99 MW respectively. Therefore, for the remaining customers, the average connected load per customer for the complex customer is around 7.8 MW.

Table 27: Summary of Connected Customer during 2024

Type of Applicant	No. of Applications	Connected load [MW]
Simple connection	34,439	1119
Complex Connection	33	702.6
Total	34,472	1821.6

These connections already implemented in the load forecast and power system analysis. All reinforcement or investment have been considered in the future investment plan as illustrated in the prewise sections.

6.3. System Constraints

Load related system constraints fall into one of two categories:

- Current constraints that can be considered DSSS obligations.
- Load related constraints based on current load growth forecasts.

The required reinforcements and equipment loadings are shown in Appendixes C, D and E give a clear picture of the anticipated constraints that may be imposed on the 33 kV network. The load flow results shown for the years 2025, 2026, and 2027 were obtained assuming that the current ongoing projects (CWIP) are expected to be completed on time and that the planned reinforcements are financed to bring them into operation. Failure to fund these reinforcements or delay in timely completion will constrain the network for three years.

APPENDIX A: DISTRIBUTION LICENCE CONDITION 33: DSCS

1. The licensee shall, within 12 months of the grant of this licence, and thereafter, on an annual basis, prepare a statement, in a form approved by the authority, showing, in respect of each of the three succeeding financial years, circuit capacity, forecast power flows and loading on each part of its distribution system and fault levels for each transmission node, together with:
 - information on the status of distribution circuit capacity and the anticipated future requirements of such capacity, including (i) applications for new Connections; and (ii) applications to Connect Generation capacity to its Systems;
 - a commentary prepared by the Licensee indicating the Licensee's views as to those parts of its Distribution System most suited to new Connections and Distribution of further quantities of electricity
 - information on what constraints are foreseen on the Licensee's Distribution System and where;
 - information relating to progress of ongoing investment in its Distribution System;
 - such further information as shall be reasonably necessary to enable any Person seeking to Connect to or use the Licensee's Distribution System to identify and evaluate the opportunities for so doing;
 - an assessment of technical losses from the Licensee's Distribution System; and
 - such other matters as shall be specified in directions issued by the Authority from time to time for the purposes of this Condition,
 - provided that the Authority may, upon application of the Licensee, relieve the Licensee from the obligation to prepare any such statement in respect of any period and any part or parts of its Distribution System specified in directions issued to the Licensee by the Authority from time to time for the purposes of this Condition.
2. The Licensee shall include in every statement prepared in accordance with paragraph 1 above the information required by that paragraph except that the Licensee may with the prior consent of the Authority omit from any such statement any details as to the capacity, flows, loading or other information, disclosure of which would, in the view of the Authority, seriously and prejudicially affect the commercial interests of the Licensee or any third party.
3. The Licensee may periodically revise the information set out in and, with the approval of the Authority, alter the form of the statement prepared in accordance with paragraph 1 and shall, at least once in every year this Licence is in force, revise such statement in order that the information set out in the statement shall continue to be accurate in all material respects.
4. The Licensee shall, when preparing the statement referred to in paragraph 1 of this Condition, ensure that the statement takes due account of information required to be provided to it by Persons bound by the Distribution Code.
5. The Licensee shall send a copy of the statement prepared in accordance with paragraph 1 and of each revision of such statement in accordance with paragraph 3 to the Authority. Each such revision shall require to be approved by the Authority and shall not become effective until approved by the Authority.
6. The Licensee shall, subject to paragraph 6, give or send a copy of the statement prepared in accordance with paragraph 1 or (as the case may be) of the latest revision of such statement in

accordance with paragraph 3 approved by the Authority pursuant to such paragraph to any Person who requests a copy of such statement.

7. The Licensee may make a charge for any statement given or sent pursuant to paragraph 4 of an amount reflecting the Licensee's reasonable costs of providing such a statement which shall not exceed the maximum amount specified in directions issued by the Authority from time to time for the purposes of this Condition.

APPENDIX B: SYSTEM STUDY RESULTS

Appendix B presents the following series of tables, for each grid substation power system model, which show the expected performance of the distribution network under maximum demand for each year from 2024 to 2027.

1. Primary Substations Maximum Demand and Percentage Loading

The maximum demand with real and reactive power loads at the PSS individual peak time in 2024 planning cycle and as accordingly forecasted for the period from 2025 to 2027. Percentage loading is calculated based on the Firm Capacity of the PSS. This data was used in the load flow and fault level studies for maximum demand scenario presented in this section of this DSCS. Below web link drives directly to all Primary Substations Maximum demand tables:

<https://mzgportal.mzec.co.om/portal/apps/webappviewer/CapabilityStatment2025-2027.xlsx>

2. 33kV Feeder Loads

The resulting maximum demand in MVA on 33kV circuits/feeders, calculated for the individual non-coincident maximum loads of the PSS(s) connected to these feeders for the period 2024 to 2027. Percentage loading is calculated based on the de-rated capacity of the circuits. Below web link drives directly to all 33kV feeders loading tables:

<https://mzgportal.mzec.co.om/portal/apps/webappviewer/33kVFeedersLoading2024to2027.xlsx>

3. Primary Substations Bus Voltages

The resulting voltage value (expressed in percentage of the nominal 33kV and 11kV) on the busbars of the PSSs, corresponding to maximum and minimum demand scenarios. Below web link drives directly to the voltage non-compliance tables:

https://mzgportal.mzec.co.om/portal/apps/webappviewer/PrimarySubstationsBusVoltages_2024-2027.xlsx

4. Primary Substation 3-Phase Fault Current Levels (kA)

The resulting 3 phase maximum fault current level on the busbars of the PSSs, corresponding to maximum demand scenarios. The rated breaking fault ratings of the switchgear are also specified. Below web link drives directly to all Primary Substation 3-Phase Fault Current Levels tables:

[https://mzgportal.mzec.co.om/portal/apps/webappviewer/ShortCircuitLevels\(kA\)_SimulationResults.xlsx](https://mzgportal.mzec.co.om/portal/apps/webappviewer/ShortCircuitLevels(kA)_SimulationResults.xlsx)

5. 11kV Feeder Loads

Below web link drives to the actual maximum demand in (Amp) on 11kV circuits/feeders for 2024 tables:

<https://mzgportal.mzec.co.om/portal/apps/webappviewer/11kVFeedersLoad2024-CS.xlsx>

Explanatory Notes:

1. **1TX** in Firm Capacity means primary substation has single 33/11 kV transformer (i.e., zero N-1 capacity and firm capacity equivalent to 11kV interconnection capacity);
2. **Standby PSS** means primary substation having 33kV and 11kV busbars energized with 11kV outgoing feeders (i.e., loads) disconnected. The load on these PSSs is expected to be connected occasionally, depending on requirement.

In the above-mentioned tables, a “-“(dash) appears in relevant years due to any of the following reasons, as may be applicable:

- The primary substation is shifted (i.e., connected) to another grid station.
- The primary substation, or any of its capacity enhancement project, is planned to be energized/commissioned in the future.
- There are no 11kV busbars (rather a different voltage level exists e.g., 6.9kV for a private customer, operated and maintained by the customer);
- NEDC doesn't own/have the information of the network below 33kV level.
- An “Outage” / “Out of Service” condition exists on concerned 33kV circuit / 33kV busbar at the day/time of the declared maximum demand of the PSS.

APPENDIX C: FUTURE SYSTEM DEVELOPMENT PLANS

No.	PIAD No.	Project Name	Wilayat	Expected Completion Year	Project Status	Project Purpose
Muscat						
1	D/06/2019	New Mabelah South 9 – [P184]	Seeb	2024	Completed	To relieve loads from Mabelah Area
2	D/02/2021	New Airport Height 6 PSS [P195]	Bousher	2024	Completed	To relieve loads from Airport Height area and accommodate the new load
3	MEDC/AMD/2/2018	Replacement of al Hamriyah PSS [P035]	Al Hamriyah	2024	Completed	Old asset replacement
4	D/07/2019	Upgrading Al Hail North 1 [P027]	Seeb	2024	Completed	To relieve loads from Al Hail Area and accommodate the new load
5	D/03/2021	Installation of 33Kv Capacitor Bank in different Grids locations	Different Locations	2024	Completed	Enhance the Network reliability and efficiency
6	D/05/2018	Madinat Al Nahdha PSS - 33kV Load Shifting to Amerat Grid from Jahloot Grid	Amerat	2024	Completed	Balance the load between the GSS and making the two 33kV feeders from the same GSS
7	D/01/2020	Upgrading Sarooj Shati Al Qurum [P110]	Bousher	2024	Execution stage	To relieve loads from Al Sarooj - Al Qurum Area
8	PIAD/REP/2019/1/1	Construction of 2X20MVA Ruwi Valley [P174]	Muttrah	2025	Execution stage	Old asset replacement and upgrading the PSS to relieve loads from the area
9	PIAD/REP/2022/2	Asset Replacement at Rusail Industrial 1 [P103]	Seeb	2025	Execution stage	Old asset replacement
10	D/03/2022	Upgrading Al Hail North 2 Upgrade [P028]	Seeb	2025	Execution stage	To relieve loads from Al Hail Area and accommodate the new load
11	D/06/2022	11kV Capacitor Banks at Primary Substations	Different Locations	2026	Tendering Stage	Enhance the Network reliability and efficiency
12	PIAD/REP/2022/4	Aziba South-1A P014 replacement of 11kV SWG	Bousher	2026	Designing Stage	Old asset replacement
13	-	Muttrah Store P085 replacement of 33kV SWG	Muttrah	2026	Tendering Stage	Old asset replacement.
14	D/02/2024	Upgrading Al Shahbari [P092] 3x220MVA	Quriyat	2026	Designing Stage	To relieve loads from Quriyat Area and accommodate the new load
15	D/01/2024	New Misfah Phase 2 PSS 3x20MVA [P200]	Seeb	2026	Designing Stage	To relieve loads from Misfah Area
16	D/03/2024	Upgrading Yenket [P133] PSS	Quriyat	2026	Designing Stage	To relieve loads from Yenket Area
17	-	MSH01 PSS	Seeb	2026	Execution Stage	To relieve loads for Madinat Al Sultan Haitham
18	-	MSH02 PSS	Seeb	2026	Execution Stage	To relieve loads for Madinat Al Sultan Haitham
19	-	MSH02 PSS	Seeb	2026	Execution Stage	To relieve loads for Madinat Al Sultan Haitham

No.	PIAD No.	Project Name	Wilayat	Expected Completion Year	Project Status	Project Purpose
19	D/04/2022	Bousher Ansab Height [P202] PSS	Bousher	2027	Tendering Stage	To relieve loads from AL Ansab Area
20	-	New Mabelah South 10 PSS	Seeb	2027	Planning Stage	To relieve loads from Mabelah Area
21	-	New Ghala 3 PSS	Bousher	2027	Designing Stage	To relieve loads from Ghala Area
Al Batinah South						
1	SB-07/2013	Construction of 3x20MVA PSS (Hay Asem) with 33kV & 11kV feeders	Barka	2024	Execution stage	To relieve loads from Rumais Primary Substation
2	TS-SB 3/2021	Upgradation Of Tekha Pss From 1X6 Mva To 2X6 Mva	Rustaq	2024	Execution stage	To relieve loads from Wadi Sahtan Primary Substation
3	SB 01/2019	Construction Al Sawadi 2x20 MVA substation with two 33 kV feeders from Blue City grid	Barka	2025	Execution stage	To relieve loads from Billah Primary Substation
4	SB-04/2013	Construction of 2x20 MVA PSS Shuaybah South at Al Musanah in Batinah South with 33 kV and 11 kV feeders.	Musanah	2025	Execution stage	To relieve loads from Jamma Temp Primary Substation
5	SB 02/2022	Construction of 2X20 MVA PSS (Khazaen) with 33&11kV feeders	Nakhla	2025	Execution stage	To provide power supply in Khazaen Economic City
6	SB 01/2022	Construction of 2X20 MVA PSS (Al Wasit) with 33&11kV feeders	Nakhla	2025	Execution stage	To relieve loads from Afi Primary Substation
Al Dakhilah						
1	DH-07/2013	Construction of Adam Bashaer 33 kV feeder from Adam grid station to supply Adam Bashaer primary substation	Nizwa	2025	Execution stage	To secure the 33 kV supply for Adam Bashaer primary substation
2	DH 06/2012	Construction of Sumail Industrial 132/33 kV grid station 2x125 MVA with 33 kV feeders	Sumail	2025	Execution stage	Relieve the load form existing Sumail New grid station
3	DH-08/2013	Construction of Birkat Al Mouz 132/33 kV grid station 2x125 MVA with 33 kV feeders	Nizwa	2025	Execution stage	Relieve the load form existing Izki and Nizwa grid stations
4	DH-02/2013	Construction of Jabal Al Akhdher one 33 kV feeder from Izki grid station to supply Jabal Al Akhdher New primary substation	Nizwa	2025	Execution stage	To secure the 33 kV supply for Jabal Al Akhdher primary substation
5	ASS-DK 1/2022	Construction of New 33 kV feeder from Samad Grid station to Sumrah 3x6 MVA primary substation	Mudhaibi-Sumail	2025	Execution stage	Feeder Sumrah PSS from Samad Grid
6		Upgrading Of Basher Primary Substation From 2X6MVA to 3X6MVA with 33KV & 11KV Feeders	Adam	2025	Execution stage	Relieve the load form Basher Primary Substation
7	DH 01/2019	Construction of Maameer 2x20 MVA Substation in Nizwa	Nizwa	2026	Execution stage	Relieve the load form existing Karsha, Maara temp and Mamad primary substations
North Sharqiyah						
1	NSH 01/2019	Construction of Al Dreez 2x20 MVA substation with two 33 kV feeders interlink with Mudhairib-3 and Mudhairib-4	Ibra	2024	Execution stage	Relieve the load from existing Al Mudhairib primary substation
South Sharqiyah						

No.	PIAD No.	Project Name	Wilayat	Expected Completion Year	Project Status	Project Purpose
1	SSH 01/2016	Construction of Wafi 2x20 MVA primary substation	Jalan Bani Bu Hassan	2025	Execution stage	Relieve the load from existing Tawi Aishah, Hadri Bilad and Kamil Water Pump primary substations
2	SH 01/2012	Construction of JBB Ali-2 2x20 MVA primary substation	Jalan Bani Bu Ali	2025	Execution stage	Relieve the load from existing Jalan Bani Bu Ali grid and Jalan Bani Bu Ali primary substations
3	SSH 02/2019	Construction of Jawabi Grid 33 kV busbar and 33 kV switchgear	Jalan Bani Bu Ali	2025	Execution stage	Relieve the load from existing Jalan Bani Bu Ali Grid Station
4	SSH 03/2016	Construction of Al Ashkhara-2 2x 20 MVA substation with two 33 kV incomers from BB Hassan Grid Station	Jalan Bani Bu Ali	2025	Execution stage	Relieve the load from existing Ashkhara primary substations
5	TS-SSH 2/2022	Modification of Sur Filayj 1x6 + 1x6 MVA substation to 2x6 MVA with additional 33 kV Tapping from feeder 15L5 Sur Grid Station	Sur	2026	Designing Stage	To comply with DSSS
6	PIAD-SSH 1/2023	Construction of Qarah 3 x 20 MVA substation with 33 kV and 11 kV feeders	Jalan Bani Bu Ali	2027	Designing Stage	Relieve the load from existing JBBA and Sauh Ramath and Qarah temp primary substations
7	D/05/2024	Construction of AL Falah Hospital 3 x 20 MVA substation with 33 kV and 11 kV feeders	Jalan Bani Bu Hassan	2027	Designing Stage	Relieve the load from existing JBBH-a primary substations and power supply to Al Falah Hospital
6	-	Constructing one 33KV circuit from JBB. Hassan to Tahaim area	JBB. Hassan	2025	Tendering Stage	Power Supply to Tahaim area
7	-	Constructing of 33KV and 11KV to overcome non-compliance of Nahddah and Ras Helf PSS	Masirah	2025	Designing Stage	To comply with DSSS
8	-	Interconnection of the Masirah distribution system with MIS by interlinked Switching Station to the Masirah Grid.	Masirah	2026	Designing Stage	Shutdown the Masirah Power Plant and reduce the OPEX cost
9	-	Interconnection of the Khuwaima distribution system with MIS by constructing 2x20MVA	Khuwaima	2026	Designing Stage	Shutdown the Khuwaima Power Plant and reduce the OPEX cost
Al Wusta						
1	Tanweer 10/2022	Constructing a new (132/33) kV Grid Station in Khuwaima area with new 33kV lines to connect Khuwaima and Juwairah Primary Substations.	Mahout	2025	Execution stage	To feed Hijj area from the Mahout Grid
2	-	Constructing a new (132/33) kV Grid Station in Khuwaima area with new 33kV lines to connect Khuwaima and Juwairah Primary Substations.	Mahout	2026	Execution stage	Shutdown Khuwaima Power Plant and reduce the OPEX cost
3	RE-WS 02/2024	Construction of 2x6 MVA PSS and 33 & 11KV Feeders (Interlinking Najdha Network to MIS) at Wilayat Mahout in Al Wusta Governorate	Mahout	2026	Designing Stage	Shutdown Najdha Power Plant and reduce the OPEX cost

No.	PIAD No.	Project Name	Wilayat	Expected Completion Year	Project Status	Project Purpose
4	-	Interconnection of the Khaloof distribution system with MIS by constructing one 33KV circuit from the Mahout network and 2x3 MVA PSS in the Khaloof area.	Mahout	2026	Execution stage	Shutdown Khloof Power Plant and reduce the OPEX cost
5	-	Extension of 33KV feeder to Um Qurshreb Village.	Mahout	2026	Planning Stage	Power Supply to Um Qurshreb Village.
AL Dhahirah						
1	2017-01	Reconstruction of 33 kV Portion of Ibri Old Grid Station- 33kV Feeders Interlinks	IBRI	2025	Execution stage	Replacing old assets and managing load between grid stations
2	2021-2	Construct New Hilat Al Nahdha PSS 3X20 with 33kV feeder from Ibri Grid	IBRI	2025	Execution stage	Cover the new loads and to relieve loads from Mazra Bani Khater Primary Substation
3	2021-5	Upgrading Baat PSS from 2X6 MVA to 2X20 MVA with 33kV feeder from Dreez Grid	Dreez	2025	Execution stage	Cover the new loads
4	2021-6	Rearrangement of 33kV network between Dreez & AL Hail Grid Stations (transfer Hugerat & Kahant to AL Hail Grid & Provide second feeding source to AL Mahual & Kahanat PSS)	IBRI	2025	Execution stage	To manage Grid Stations loading and provide second 33kV feeding source to AL Mahual and Kahanat PSSs
5	2022-1	Construction of Ibri Industrial 2x6 MVA Primary Substation	IBRI	2025	Execution stage	Providing secure supply to new Industrial Area
6	2021-2	Upgrade AL Akhdar PSS from 2x10 to 2x20 and Shift from Ibri TX1 & TX2 Grid Station to IBRI Old Tx3 & Tx4	IBRI	2025	Designing Stage	Cover the new loads
7	-	Upgrading of Hugerat from 2X10 MVA to 2x20 MVA Primary Substation	Dreez	2027	Planning Stage	To relieve load from Hugerat, Maqnyat and Substations
8	D/04/2024	Construction of Mashrooh 2x6 MVA Primary Substation	DANK	2027	Planning Stage	To relieve load from Al Rayhani
9	-	Construction of Maskin 2x6 MVA Primary Substation	DREEZ	2027	Planning Stage	To relieve load from Al Nujayd
North Batinah						
1	2021-1	Upgrade Sana Bani Gafer PSS From (2 x 6 MVA) to (2 x 20 MVA) with 33KV feeder interlinks to S.B.G PSS and AL Lehban PSS	Al Khabourah	2025	Execution stage	Cover the new loads
2	Business Case (2022-02)	33kV feeder interlinks to provide second feeding source for Wadi Ahin, Hail Al Asskareen , wadi Al Hilti and Hay Al Rafaa PSSs.	Sohar	2025	Execution stage	Providing second feeding source to comply with DSSS

No.	PIAD No.	Project Name	Wilayat	Expected Completion Year	Project Status	Project Purpose
3	2021-4	Upgrading AL Wajajah PSS from 2X3 MVA to 2X6 MVA with connect new 33kV feeder from MD Shinas Grid	Shinas	2026	Designing Stage	Cover the new loads
4	Business Case (2024-3)	Transferring and Converting Falaj AL Qbail 1 PSS 33kV feeders from Suhar Industrial Port Grid to SFZ Grid	Sohar	2026	Planning Stage	Load Managing between Grid Stations
5	2024-2	Construct New SIET-6 (Phase 7) PSS 3X20 MVA	Sohar	2027	Designing Stage	Providing secure supply to Sohar Industrial Estate phase 7
6	-	Upgrade of Al Huwail 1 from 2 x 20 MVA to 3x20 MVA	SAHAM	2027	Planning Stage	To relieve load from Mukhalif Jadeedah, Al Huwail 2 and Hilat al Suq
7	-	Construction of Murtfaat Al Hambar 3x20 MVA Primary Substation	Sohar	2027	Planning Stage	To relieve load from Al Muwailh 2 and Palm Garden Substations
Musandam						
1	2019-4	Upgrading Siwi PSS from 2X6 MVA to 2X20 MVA with installing new 33kV feeder from Khasab Grid Station	Khasab	2025	Execution stage	Cover the new loads
2	-	Modification to secure Musandam Network	Khasab	2026	Designing Stage	Securing Khasab loads
3	-	New Khasab Port PSS (2X20 MVA) with Two 33kV Feeders	Khasab	2026	Designing Stage	Securing Khasab loads

APPENDIX D: SPONSORED PROJECTS

No.	Reference No.	Project Name	Wilayat	Expected Completion Year	Project Status	Purpose
Muscat						
1	-	Improve Reliability at MOD MAM-B PS By Adding One New 33kV Feeder	Seeb	2025	Execution stage	The connection will be made by tapping on the existing 33kV cables passing near the AFH which are fed from Rusail Industry Grid(G13) and feeding Rusail B PSS and adding circa 1km of new 33kV sections form the tapping points.
Al Batinah South						
1	CC/5/2017	Construction of Al Hazam Water Pump 2x6 MVA substation with 33 kV feeders from Muladah Grid	Musanah	2024	Completed	To meet Customer load required
2	CC/2/2018	Construction of Hay Al Sharq 2x20 MVA substation	Barka	2024	Completed	To meet Customer load required
Al Dhakilyah						
1	CC/20/2018	Construction of 3x20 MVA ROP College primary substation	Nizwa	2024	Completed	To meet Customer load required
2	CC/10/2018 (CC/26/2017)	Construction of 2x10 MVA Al Ain Water Pump primary substation	Samail	2024	Completed	To meet Customer load required
3	CC/11/2018 (CC/27/2017)	Construction of 2x10 MVA Hub 2 Water Pump primary substation	Samail	2024	Completed	To meet Customer load required
4	CC/9/2018 (CC/25/2017)	Construction of 2x20 MVA Hameem Water Pump primary substation	Samail	2024	Completed	To meet Customer load required
5	MZ23IC03209-ND/D/1081/2023	Construction of 2x33 kV feeder from Samail Industrial 132/33 kV grid station 2x125 MVA for Al Thail Metal Recycling LLC	Samail	2025	Execution stage	To meet Customer load required
North Sharqiyah						
1	MZ191C03217	Construction of Al Hadeetha 2x20 MVA with two 33 kV feeders	Mudhaibi	2024	Completed	To supply the requested load of Al Wadi Endam Mine project